

**MULTIPLE DOORS CHECKLIST**

Cite: <b>POLICE</b>	Question:	Door: E Door #: Police main entry	Door: I Door #: Chief's room	Door: I Door #: Chief's closet	Door: I Door #: Chief RR	Door: I Door #: Chief office	Door: E Door #: Employee entry	Door: I Door #: Lt office	Door: I Door #: Lt Closet	Door: I Door #: Hall closet
<b>If a double door, measure only the active leaf</b>										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	Yes	No: wall back on pull, shredder ( <a href="#">CH11</a> , <a href="#">CH12</a> )	No: sink back, desk on pull ( <a href="#">CH13</a> )	Yes	Yes	No: chair on pull ( <a href="#">CH18</a> )	No: storage int. ( <a href="#">CH110</a> )	No entry ( <a href="#">CH21</a> )
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	No: 2.9% ( <a href="#">CH6</a> , <a href="#">CH7</a> )	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No: stairs encroach ( <a href="#">CH20</a> )	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	No: 27.5" ( <a href="#">CH10</a> )	No: 27.5"	Yes	Yes	n/a	No: 28.25" ( <a href="#">CH19</a> )	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	No: 1.25" ( <a href="#">CH8</a> )	Yes	Yes	Yes	n/a	No: 1" ( <a href="#">CH15</a> , <a href="#">CH17</a> )	Yes	n/a	Yes
404.2.5	Thresholds < 1/2 "	Yes	n/a	n/a	n/a	n/a	Yes	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	Yes	Yes	Yes	Yes	n/a	Yes	Yes	Yes
302.3	If openings in floor, <1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No: knob ( <a href="#">CH21</a> )

Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	No: 8#	n/a	n/a	n/a	n/a	No: 7#	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 13#	n/a	n/a	n/a	n/a	No: 9#	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	Yes	n/a	n/a	n/a	Yes	Yes	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	Yes	No: 47.5" ( <a href="#">CH9</a> )	n/a	n/a	n/a	No: 52" ( <a href="#">CH16</a> )	n/a	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a								
Other:										

Rev. 04/21/14

Cite: <b>POLICE</b>	Question:	Door: I Door #: City file room	Door: I Door #: Conference 1	Door: I Door #: Conference 2	Door: I Door #: stairwell	Door: I Door #: Sargent Millroy	Door: I Door #: Special services	Door: I Door #: Adult investigation s	Door: I Door #: Lt 2	Door: I Door #: Juvenile invest
<b>If a double door, measure only the active leaf</b>										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: storage ( <a href="#">CH114</a> )	No: counter on pull ( <a href="#">CH24</a> )	No: counter on pull ( <a href="#">CH23</a> )	No: stairs	No: chair back ( <a href="#">CH26</a> )	Yes	No: recessed, shelf on pull ( <a href="#">CH29</a> )	No: cabinet on pull ( <a href="#">CH28</a> )	No: chair on pull ( <a href="#">CH30</a> )
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	No: 33.5" ( <a href="#">CH22</a> )	n/a	n/a	n/a	No: 33" ( <a href="#">CH25</a> )	n/a	No: 33.75" ( <a href="#">CH27</a> )	n/a	n/a
303.2	Change in level < 1/4"	Yes	Yes	Yes	n/a	Yes	Yes	Yes	Yes	Yes
404.2.5	Thresholds < 1/2 "	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

302.2	If carpeted is pile < ½"	Yes	Yes	Yes	n/a	Yes	Yes	Yes	Yes	Yes
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	No: 7#	No: 6#	No: 7#	No: 7#	No: 8#	No: 6#	No: 10#	No: 7#
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	Yes	Yes	Yes	No	No	No	Yes	No
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a								
404.2.6	Series of doors clearance (48” clear width, doors open)	n/a								
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a								
Other:										

Cite:	Question:	Door: I Door #: hallway	Door: I Door #: Break room	Door: I Door #: Break RR	Door: I Door #: Dispatch	Door: I Door #: Records	Door: I Door #: Electronics	Door: I Door #: Hall to custody	Door: I Door #: W LR	Door: I Door #: Restroom near int. rooms
<b>If a double door, measure only the active leaf</b>										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: wall on both at 11” (CH31)	No: table back and garbage on pull (CH37, CH38)	No: sink back (CH209)	No: desk and cabinet on pull (CH36)	Yes	No: IT back on push (CH44)	No: walls on both sides (CH48)	No: garbage on pull, bench back (CH49, CH150)	No: sink on push (CH220)
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	No: 3.7% on int (CH40, CH41)	Yes	Yes	Yes	Yes
307.4	80” Head Clearance (excl. closer; min 78”)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32”; with no projections > 4”	Yes	Yes	No: 27.25”	Yes	Yes	Yes	Yes	Yes	Yes

	between 34" and 80"?			<a href="#">(CH211)</a>						
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	No: 35" <a href="#">(CH47)</a>	n/a	n/a
303.2	Change in level < 1/4"	Yes	n/a	n/a	n/a	Yes	Yes	n/a	n/a	n/a
404.2.5	Thresholds < 1/2 "	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	Yes	n/a	n/a	Yes	n/a	n/a	n/a	n/a	n/a
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	No: knob	No: knob	Yes	Yes	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	No: 9#	No: 7#	n/a	n/a	n/a	n/a	No: 7#	No: 7#	n/a
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	No	Yes	n/a	n/a	n/a	n/a	Yes	No	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

	smooth or have a kick plate? (horizontal gap 1/16" max)									
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	No: 48.5" (CH33)	No: 48" (CH34)	n/a	n/a	n/a	n/a	No: 48.25" (CH46)	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Other:										

Cite:	Question:	Door: I Door #: Lab	Door: E Door #: Side exit near int. rooms	Door: I Door #: Interrogatio n A/B (2 doors)	Door: I Door #: Intoxilizer room	Door: E Door #: Exit from squad	Door: I Door #: Sargent Office	Door: I Door #: Training room	Door: I Door #: Report writing	Door: I Door #: Armory
	<b>If a double door, measure only the active leaf</b>									
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: cabinet on pull (CH50)	No: wall at 14" (CH51)	No: A has cabinet (CH56); B has bench back (CH58)	No: shelf back, small room (CH60)	No: garbage and chairs on pull (CH61, CH62); stairs on push	No: cabinets back on pull (CH67)	No: shelf on pull (CH68)	No: garbage on pull (CH69)	Yes

						(CH64)				
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	No: 8.8% (CH52, CH53)	Yes	Yes	No: 4.2% (CH63, CH64)	Yes	Yes	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	No: 29.5" (CH55)	No: 27.5" (CH59)	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	n/a	n/a	n/a	Yes	No: 4" (CH65)	n/a	n/a	n/a	n/a
404.2.5	Thresholds < 1/2 "	n/a	Yes	n/a	n/a	Yes	n/a	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.3	If openings in floor, <1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No: pull small handle (CH71)	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

Building/Year built: Police Station/City Hall  
 Date: 11/11/2015

Team: Shelley Zuniga, Dana Esposito  
 Job#: R15025

404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	No: 7#	No: 10#
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	No: 9#	n/a	n/a	No: 9#	n/a	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	No	n/a	n/a	No	n/a	n/a	Yes	No
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	No: 52" (CH54)	No: 52.5" (CH57)	n/a	No: 52.25" (CH66)	n/a	n/a	No: 48" (CH72)	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Other:										

Cite: <b>POLICE</b>	Question:	Door: I Door #: Fitness	Door: I Door #: LR men's	Door: I Door #: To lobby	Door: I Door #: Public RR	Door: I/E Door #:				
------------------------	-----------	-------------------------------	--------------------------------	--------------------------------	---------------------------------	----------------------	----------------------	----------------------	----------------------	----------------------

If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: treadmill on pull (CH74)	Yes	No: shelf on pull	No: drug drop off on pull, brochure shelf (CH2, CH4)					
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes					
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes					
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	No: 31" (CH78)	Yes	Yes					
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a					
303.2	Change in level < 1/4"	Yes	n/a	Yes	n/a					
404.2.5	Thresholds < 1/2 "	n/a	n/a	n/a	n/a					
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a					
302.2	If carpeted is pile < 1/2"	n/a	n/a	n/a	n/a					
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a					
309.4; 404.2.7	Door hardware compliant?	No: small (CH75)	n/a	Yes	Yes					
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a					
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes					
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a					
11B-	Do power doors have	n/a	n/a	n/a	n/a					

Building/Year built: Police Station/City Hall  
 Date: 11/11/2015

Team: Shelley Zuniga, Dana Esposito  
 Job#: R15025

404.3.5	two push plates, one at 7"-8" aff and the other 30"-44" aff?									
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	No: 8#	n/a	No: 7#	No: 8#					
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a					
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	n/a	Yes	No					
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes					
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	No: 48" (CH73)	n/a	No: 52.25" (CH1)	n/a					
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a					
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a					
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	Yes	n/a	n/a					
Other:										

Cite: <b>COUNCIL CHAMBERS</b>	Question:	Door: E Door #: Council chambers entry	Door: I Door #: Back room	Door: I Door #: Back room closet	Door: I Door #: Double to hall	Door: E Door #: Hall exit	Door: I Door #: Hall women's RR	Door: I Door #: Hall men's RR	Door: E Door #: Front entry to RR	Door: I/E Door #:
<b>If a double door, measure only the active leaf</b>										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: table on push ( <a href="#">CH239</a> )	No: flag on pull side ( <a href="#">CH243</a> )	No: storage int ( <a href="#">CH252</a> )	Yes	No: 10.5" to wall on push ( <a href="#">CH257</a> ); garbage, chair on pull ( <a href="#">CH260</a> , <a href="#">CH261</a> )	Yes	Yes	Yes	
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	No: 10.3% slope ( <a href="#">CH229</a> , <a href="#">CH230</a> )	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
303.2	Change in level < 1/4"	Yes	No: 7.75" ( <a href="#">CH244</a> )	n/a	n/a	No: 3" ( <a href="#">CH258</a> , <a href="#">CH259</a> )	Yes	Yes	Yes	
404.2.5	Thresholds < 1/2 "	Yes	n/a	n/a	n/a	Yes	Yes	n/a	No: lipped	
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
302.2	If carpeted is pile < 1/2"	Yes	Yes	n/a	Yes	Yes	n/a	n/a	n/a	
302.3	If openings in floor, <1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	

309.4; 404.2.7	Door hardware compliant?	Yes	Yes	No: knob ( <a href="#">CH251</a> )	Yes	Yes	No: small on pull ( <a href="#">CH263</a> )	No: small	Yes	
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	No: 7#	n/a	No: 7#	No: 6#	n/a	
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 8#	n/a	n/a	n/a	No: 6#	n/a	n/a	No: 6#	
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	n/a	n/a	No	Yes	Yes	Yes	Yes	
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	No: 43.5" ( <a href="#">CH231</a> )	n/a	n/a	No: 52.5" ( <a href="#">CH256</a> )	No: 43.25" ( <a href="#">CH262</a> )	n/a	n/a	No: 43.5"	
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	

Building/Year built: Police Station/City Hall  
Date: 11/11/2015

Team: Shelley Zuniga, Dana Esposito  
Job#: R15025

404.2.6	Series of doors clearance (48" clear width, doors open)	n/a								
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a								
Other:										

Cite:	Question:	Door: E Door #:	Door: I Door #:	Door: I Door #:	Door: I Door #:	Door: E Door #:	Door: I Door #:	Door: I Door #:	Door: I Door #:	Door: I Door #:
<b>CITY HALL</b>		City hall main entry	Finance	Laurie's office	Server room	Hall storage	Furnace room	Men's RR	Women's RR	Building department
<b>If a double door, measure only the active leaf</b>										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	Yes	No: file cabinet on pull ( <a href="#">CH301</a> )	No: file desk on pull ( <a href="#">CH303</a> )	No: supplies on pull ( <a href="#">CH307</a> )	No: blocked with storage ( <a href="#">CH310</a> )	No: 40" back on pull ( <a href="#">CH315</a> )	No: 10" to wall on push ( <a href="#">CH324</a> )	No: shelf on pull ( <a href="#">CH337</a> )
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	No: 1" CIL under mat ( <a href="#">CH278</a> )	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	No: doesn't open to 90 ( <a href="#">CH308</a> )	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	No: 1" threshold	n/a	n/a	Yes	Yes	n/a	Yes	Yes	n/a

		(CH279)								
404.2.5	Thresholds < ½ "	No	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < ½"	Yes	Yes	Yes	Yes	Yes	n/a	n/a	n/a	Yes
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	No: small on pull (CH314)	No: small on pull	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	No: 6#	No: 7#	Yes	n/a	n/a	No: 8#	No: 7#	No: 7#
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 7#	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	Yes	Yes	Yes	n/a	n/a	Yes	Yes	Yes
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

	1/16" max)									
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	No: 43.5" (CH281)	No: 47.25" (CH292)	No: 45.25" (CH298)	No: 45.75" (CH302)	n/a	n/a	n/a	n/a	No: 47.75" (CH338)
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Other:										

Cite:	Question:	Door: I Door #: Michelle office	Door: I Door #: Taylor office	Door: I Door #: Spare office	Door: I Door #: Planning library	Door: E Door #: Exit near building department	Door: I Door #: Tracey's office	Door: I Door #: Steve's office	Door: E Door #: Steve's exit	Door: I Door #: Tracey closet
	<b>If a double door, measure only the active leaf</b>									
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: desk back and cabinet on pull (CH339, CH340)	No: chair back on pull (CH378)	No: desk back (CH343), file cab on pull (CH342)	No: file cabinet on push (CH344, CH348)	No: wall on push, railing back on pull	No: chair back on pull (CH359)	Yes	No: table on pull (CH360)	No entry
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No: 27.5" ( <a href="#">CH362</a> )
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	n/a	n/a	n/a	n/a	No: 3.5" ( <a href="#">CH356</a> )	n/a	n/a	No: 3" ( <a href="#">CH361</a> )	n/a
404.2.5	Thresholds < 1/2 "	n/a	n/a	n/a	n/a	Yes	n/a	n/a	Yes	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	Yes	n/a	n/a	n/a	Yes	n/a	n/a	n/a
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No: knob ( <a href="#">CH360</a> )	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a	n/a	Yes	n/a	n/a	n/a
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a	No: 7#	n/a	n/a	n/a	n/a

404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	n/a	n/a	n/a	Yes	Yes	n/a	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	n/a	n/a	n/a	No: 50.25" <a href="#">(CH357)</a>	No: 47.75"	n/a	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	No: small <a href="#">(CH363)</a>
Other:										

Cite:	Question:	Door: I Door #: Single RR in break	Door: E Door #: Exit near copier	Door: I Door #: Kirsten office	Door: I Door #: Building inspector	Door: I Door #: L building office	Door: I Door #: R building office	Door: I/E Door #:	Door: I/E Door #:	Door: I/E Door #:
<b>If a double door, measure only the active leaf</b>										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: sink on pull	No: 16" to ramp edge <a href="#">(CH389)</a>	No: file cabinet on pull <a href="#">(CH373)</a> ,	No: garbage on pull <a href="#">(CH390)</a>	No: cabinets on push; <a href="#">(CH391)</a>	Yes			

				<a href="#">CH374</a>		shelf on pull <a href="#">(CH392)</a>				
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	No: 6.2% slope <a href="#">(CH387, CH388)</a>	Yes	Yes	Yes	Yes			
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes			
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	No: 27" <a href="#">(CH384)</a>	Yes	Yes	Yes	No: reduces to 28" at cabinets to enter <a href="#">(CH399, CH400)</a>	Yes			
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a			
303.2	Change in level < 1/4"	n/a	Yes	Yes	n/a	n/a	n/a			
404.2.5	Thresholds < 1/2 "	n/a	Yes	n/a	n/a	n/a	n/a			
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a			
302.2	If carpeted is pile < 1/2"	n/a	n/a	Yes	Yes	Yes	Yes			
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a			
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes			
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a			
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes			
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a			

11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a			
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	Yes	n/a	n/a	No: 6#	n/a	n/a			
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	No: 6#	n/a	n/a	n/a	n/a			
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	Yes	n/a	Yes	n/a	n/a			
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes			
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	No: 43.5"	n/a	No: 47.75"	n/a	n/a			
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a			
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a			
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	No: small			
Other:										