

Cite	ELEMENT: SIGNAGE	Yes	No	n/a	Notes:																		
	<b>Permanent Space Signage:</b> signs designating permanent spaces and rooms; ie: restrooms, mechanical rooms, locker rooms																						
703.1	Do signs have both visual and tactile characters?		X		Lacks Braille on room signage; signs high above doors in police station ( <a href="#">CH32</a> )																		
11B-703.4.1	Is sign installed so that sign is mounted 48" min. to the baseline of the lowest Braille cells and 60" max to the baseline of the highest line of raised characters?		X		Only one restroom in lobby of police with Braille ( <a href="#">CH212</a> , <a href="#">CH313</a> )																		
703.5.5	Are letters the correct height based on the chart below? <table border="1" data-bbox="323 527 1228 1214"> <thead> <tr> <th>Height to Finish Floor /Ground From Baseline of Character</th> <th>Horizontal Viewing Distance</th> <th>Minimum Character Height</th> </tr> </thead> <tbody> <tr> <td rowspan="2">40" to 70"</td> <td>Less than 72"</td> <td>5/8"</td> </tr> <tr> <td>More than 72"</td> <td>5/8", plus 1/8" per foot of viewing distance above 72"</td> </tr> <tr> <td rowspan="2">70+'' to 120''</td> <td>Less than 180''</td> <td>2''</td> </tr> <tr> <td>More than 180''</td> <td>2'', plus 1/8'' per foot of viewing distance above 180''</td> </tr> <tr> <td rowspan="2">120+''</td> <td>Less than 21'</td> <td>3''</td> </tr> <tr> <td>More than 21'</td> <td>3'', plus 1/8'' per foot of viewing distance above 21'</td> </tr> </tbody> </table>	Height to Finish Floor /Ground From Baseline of Character	Horizontal Viewing Distance	Minimum Character Height	40" to 70"	Less than 72"	5/8"	More than 72"	5/8", plus 1/8" per foot of viewing distance above 72"	70+'' to 120''	Less than 180''	2''	More than 180''	2'', plus 1/8'' per foot of viewing distance above 180''	120+''	Less than 21'	3''	More than 21'	3'', plus 1/8'' per foot of viewing distance above 21'			X	
Height to Finish Floor /Ground From Baseline of Character	Horizontal Viewing Distance	Minimum Character Height																					
40" to 70"	Less than 72"	5/8"																					
	More than 72"	5/8", plus 1/8" per foot of viewing distance above 72"																					
70+'' to 120''	Less than 180''	2''																					
	More than 180''	2'', plus 1/8'' per foot of viewing distance above 180''																					
120+''	Less than 21'	3''																					
	More than 21'	3'', plus 1/8'' per foot of viewing distance above 21'																					
703.2, 216.2, 703.3, 703.5	Do interior and exterior signs designating permanent rooms and spaces have both tactile and Braille lettering?			X																			
216.4.1, 703.1, 703.2, 703.5	Do exit signs have visual, tactile and Braille lettering? EXIT STAIR DOWN, EXIT STAIR UP, EXIT RAMP DOWN, EXIT RAMP UP, EXIT ROUTE (to enclosure), TO EXIT (direct exit)		X																				

Cite	ELEMENT: SIGNAGE	Yes	No	n/a	Notes:
CA: 1011.4					
703.6.2, 703.7.1	Does lettering and symbol of accessibility contrast with the background and have a non-glare finish?			X	
703.6.1	For pictograms, is the pictogram field 6" min with text descriptions and Braille below and outside of the pictogram field?			X	
703.3.2	Is Braille provided below the text, if multi-lined is it below the entire text body?			X	
703.2.2 703.5.3	Are raised characters in upper case and conventional in form?			X	
703.2.3 703.2.1	Are raised characters on signs between 5/8" to 2" high and raised at least 1/32"?			X	
703.4.2	Are signs with tactile characters located in the correct location with an 18" x 18" CFS for an approach to signs? <ul style="list-style-type: none"> <li>• With closers - latch side, or push side of door if no door stop</li> <li>• Without closers- latch side</li> <li>• Double with one active leaf- door mounted on inactive leaf</li> <li>• Double with two active leafs-right of the right hand door</li> </ul>			X	
	<b>Informational/Directional Signage</b> – signs providing information or direction to interior spaces (excluding company logos, temporary signage, menus, occupant names, building addresses, building directories)			X	
216.3 703.5	Do directional and informational signs have visual characters that comply with 703.5.5? (see table above)			X	
703.5.1	Does the lettering contrast with the background and have a non-glare finish?			X	
703.2.3	Is lettering conventional in style? (no italics, scripts, etc)			X	
703.5.6	Are visual characters 40" min above the ground?			X	
	<b>Entry Signage</b>			X	
216.6	If the entrance is not accessible, is there directional signage indicating the nearest accessible entry?			X	
216.6	Are accessible entries identified with the symbol of accessibility?		X		

Rev. 07/31/13