

MULTIPLE DOORS CHECKLIST

Cite:	Question:	Door: E Door #: Main entry	Door: I Door #: Dble near kitchen	Door: I Door #: Kitchen	Door: E Door #: Kitchen exit	Door: E Door #: Great room near kitchen	Door: E Door #: Great room exit near closet	Door: I Door #: closet	Door: I Door #: Storage with sink from great room	Door: I Door #: Storage w/sink from hall
If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	Yes	No: fire ext and counter back (CC3)	No: fridge on pull (CC6)	Yes	No: narrow pad (CC12)	No: storage on int (CC13)	No: counter on pull (CC14)	Yes
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	No: 2.7% slope (CC1, CC2)	Yes	Yes	Yes	Yes	No: 6% (CC9, CC10)	Yes	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	Yes	Yes	Yes	No: .5" (CC5)	No: 1" (CC7, CC8)	No: .5" (CC11)	Yes	Yes	Yes
404.2.5	Thresholds < 1/2 "	Yes	n/a	n/a	Yes	Yes	Yes	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	Yes	Yes	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.7	Hardware height (34"- 44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	No: 9#, 10#	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 11#, 10#	n/a	n/a	n/a	No: 11#	No: 11#	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	Yes	n/a	n/a	Yes	Yes	n/a	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	Yes	n/a	n/a	n/a	Yes	n/a	n/a	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

Other:										
--------	--	--	--	--	--	--	--	--	--	--

Rev. 04/21/14

Cite:	Question:	Door: I Door #: Single from great room	Door: I Door #: Dble from great room	Door: I Door #: Men's RR	Door: I Door #: Janitor closet	Door: I Door #: Women's RR	Door: E Door #: Exit to breezeway from main	Door: E Door #: Chamber entry	Door: I Door #: Chamber office	Door: E Door #: Chamber entry
If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	Yes	Yes	No: too small (CC15)	Yes	No: 15.5" on pull side (CC16)	No: table on push (CC60)	No: desk on pull (CC20)	No: storage, 6" to wall on pull (CC23)
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	n/a	Yes	Yes	Yes	Yes	No: 1.5" (CC18 , CC19)	Yes	Yes	No: 1" (CC21 , CC22)
404.2.5	Thresholds < 1/2 "	n/a	n/a	n/a	n/a	n/a	No: lip	Yes	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	n/a	n/a	n/a	n/a	n/a	n/a	Yes	n/a
302.3	If openings in floor, <1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware	Yes	Yes	No: small	No: knob	No: small	Yes	Yes	Yes	No: knob

	compliant?			(CC100)						
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	No: 7# both	No: 15#	n/a	No: 12#	n/a	n/a	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a	n/a	No: 10#	No: 12#	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	Yes	Yes	n/a	No	Yes	No	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	Yes	n/a	n/a	n/a	Yes	Yes	n/a	Yes
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

	open)									
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a								
Other:										

Cite:	Question:	Door: I Door #: Office to short hall	Door: I Door #: ED chamber office	Door: E Door #: ED exit	Door: I Door #: Chamber ED to hall	Door: E Door #: Back exit from chamber	Door: E Door #: Kiln	Door: I Door #: Kiln room/2 classrooms	Door: E Door #: Ext from classrooms	Door: E Door #: 2 Storage rooms by entry
If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: desk on pull, storage on push (CC24)	No: counter and storage on both sides (CC25)	No: bushes on pull (CC26)	No: storage and desk back on pull (CC27)	No: wall on pull (CC29)	No: counter back (CC138)	Yes	Yes	Yes
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	No: 2.7% slope (CC30 , CC32)	Yes	Yes	Yes	No: 6.9% breaker room (CC35 , CC36), 4.6% ext storage (CC37 , CC38)
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4"	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

	between 34" and 80"?									
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	No	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	Yes	n/a	Yes	Yes	No: 1" (CC31)	Yes	n/a	No: .75"	Yes
404.2.5	Thresholds < 1/2 "	n/a	n/a	Yes	n/a	No: lip	Yes	n/a	Yes	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	Yes	Yes	Yes	Yes	n/a	n/a	n/a	n/a	n/a
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	n/a	Yes	Knob
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a	No: 10#	No: 20#	n/a	No: 11# both	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	n/a	n/a	n/a	Yes	Yes	n/a	Yes	n/a
404.2.10	Is the surface of the door from floor to 10"	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

	aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)									
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	n/a	n/a	n/a	Yes	Yes	No: 55" (CC34)	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a						
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a						
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a						
Other:										