

CITE ELEMENT: KITCHENS YES NO n/a NOTES:

| CITE | ELEMENT: KITCHENS | YES | NO | n/a | NOTES: |
|--------------|--|-----|----|-----|---|
| | Is this an employee work kitchen, program kitchen or break room? Please specify. | | | | |
| 804.2.1 | Kitchens/Kitchenettes: a room or space with fixed or built-in range, cooktop, oven, microwave, or convection oven. Appliance is considered to be fixed or built-in if it is attached to a cabinet, shelf, or wall or is connected to plumbing or gas. <i>In a pass through kitchen(two opposing walls), is there 40" min clearance between the furthest projecting face of all opposing base cabinets, counter tops, appliances or walls, excluding hardware?</i> Applicable only if the kitchen has an oven | | | X | |
| 804.2.2 | <i>In a U-shaped kitchen (three continuous walls), is there a 60" min clearance?</i> Applicable only if the kitchen has an oven | | X | | 33.25" to sink island (CC64 , CC65) |
| 804.5 811 | Is at least 50 percent of cabinet shelf storage space within reach range 15" to 48" max? (reach range to supplies) (46" max aff when shelving is 10"min - 24"max deep.) (safe harbor RR - 9" - 54") | X | | | |
| 212.3 | Sinks: Are at least 5% but no less than one of each type of sink in each accessible room or space accessible? | | X | | |
| 606.3 | Is the sink installed with the front of the higher of the rim or counter surface 34" max aff? | | X | | 36" (CC66) |
| 309 | Is the sink hardware operable without a tight pinch or grasp? | X | | | |
| 606.5 | Is there insulation at all exposed pipes? | | | X | |
| 606.2 | Is there knee clearance 27h, 30w, and 8d under the sink? | | X | | Cabinet (CC67) |
| 804.3 | Ovens:(residential dwellings only) If an oven is provided, is there a work surface measuring 30" wide mounted 34" high max with knee and toe clearance? (The work surface shall be located adjacent to the latch side of the side-hinged oven door, adjacent to one side of the bottom-hinged oven door). | | | X | |
| 804.6.5.3 | Ovens: (All) Do the ovens have controls on front panels? | | X | | Side (CC68) |
| 804.6.6 | In refrigerator/freezers is at least 50 percent of the freezer space 54" max aff? | X | | | |

Building/Year built: Scotts Valley CC
 Date: 11/9/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

| CITE | ELEMENT: KITCHENS | YES | NO | n/a | NOTES: |
|------------------------|---|-----|----|-----|---|
| 804.6.6 | Parallel approach: Does the clear floor space for a parallel approach extend 48" back from the centerline of the appliance? | X | | | |
| 403.5.1 | Is there a 36" wide access aisle to move freely about the room and to all aspects of the room/space? | | X | | Reduces to 33" around island |
| 307.4 | Is there at least 80" vertical head space along the accessible route? | X | | | |
| 304.3.1 304.3.2 | Are there sections of the route that are 60" wide and allowing for turning or T shaped? | X | | | |
| 307.2 | Is the room free of protruding objects? (nothing greater than 4" between 27-80" aff) | | X | | Exhaust door controls 6" (CC71) |
| 302.1 | Are the floor surfaces of the room/space firm, stable and slip resistant? | X | | | |
| 303.4 | Where there are changes in level greater than 1/2" is there a ramp provided that has a slope no greater than 1:12? | | | X | |
| 302.3 | Are any gaps in the floor .5" or less? | | | X | |
| 403.3 | Is the slope of the floor surface no greater than 5% running or 2.08% cross and surface firm, stable and slip resistant? | X | | | |
| 804.6.1 804.6.3 | Is there clear floor space around fixtures, operable parts, and appliances? (C.F.S at dishwasher may be adjacent to the dishwasher door; however the door can not obstruct the clear floor space, clear floor space at work surfaces and appliances can be shared) | | X | | Garbage at outlets (CC73) |
| 308/309 804.6.2 | Is at least one of each type of operable parts within reach range and operable without a tight pinch or grasp? (Appliance doors and door latching devices can be operated by a tight pinch or grasp) | | X | | Counter at 36" (CC62 , CC63) 73" to buttons on exhaust control (CC72) 58.5" to phone (CC74) 61" to oven control (CC75) |
| 702 | If an alarm exists, is it a visual/audible alarm if kitchen is a public space? Otherwise is there an alarm in hearing distance? | | | X | |
| 207.1 | Does the room/space have an accessible means of egress? | | X | | |

Rev. 4/21/14