

| | Rooms/Spaces: E = denotes employee space P=public | fl#: P main room | fl#: E office | fl#: E storage | fl#: E janitor | fl#: E pantry | Notes: E = employee; P = public |
|--------------------|--|------------------------|------------------|-------------------|-------------------|------------------|---|
| 403.5.1 | Is there a 36" wide access aisle to move freely about the room and to all aspects of the room/space? (can reduce to 32" for a max of 24" if there is CFS on either side) | No | No | Yes | No | No | Office: reduces to 28" to chairs (SC108 , SC109) Janitor: too small for entry (SC112) Pantry: room only 34" wide (SC114) Main: Reduces to 25" at storage in corner (SC127 , SC128 , SC129) |
| 307.4 | Is there at least 80" vertical head space along the accessible route? | Yes | Yes | No | | Yes | Storage: shelf at 68.5" (SC110) |
| 304.3.1 304.3.2 | Are there sections of the route that are 60" wide and allowing for turning or T shaped? (60" square w/36" arms) | Yes | No | No | | No | Office: furniture Storage: small, storage (SC111) |
| 307.2 | Is the room free of protruding objects? (nothing greater than 4" between 27"-80" aff) (handrails can protrude 4.5") | No | Yes | Yes | | Yes | Main: overhead cabinets 77", TV and shelf 17" deep (SC99 , SC100) |
| 302.1 | Are the floor surfaces of the room/space firm, stable and slip resistant? | Yes | Yes | Yes | | Yes | |
| 302.2 | If carpeted, are edges securely fastened, and pile < .5" | n/a | Yes | n/a | | n/a | |
| 303.2 303.3 | Are CIL .25" max? If CIL is between .25" and .5" is beveled w/max slope 1:2? | n/a | n/a | n/a | | n/a | |
| 303.4 | Where there are changes in level greater than .5" is there a ramp provided that has a slope no greater that 1:12? | No | n/a | n/a | | n/a | Main: stage (SC101) |
| 302.3 | Are any gaps in the floor .5" or less? (.5" elongated gaps must be perpendicular to path of travel) | n/a | n/a | n/a | | n/a | |
| 403.3 | Is the slope of the floor surface no greater than 5% running or 2.08% cross and surface firm, stable and slip resistant? | Yes | Yes | Yes | | Yes | |
| 305.3 | Is there clear floor space around fixtures and operable parts? (30" by 48") | No | Yes | No | | No | Main: table at coffee station (SC103) Storage: storage (SC111) Pantry: hooks behind door |

CITE

ELEMENT: ROOMS/SPACES

Yes/No/n/a

| | | | | | | | |
|--------|---|-----|-----|-----|--|-----|--|
| 308 | Is at least one of each type of operable parts within reach range? (ie: windows) <i>Forward unobstructed</i> - 15" to 48" (max 20" over object); <i>forward high obstructed</i> - max 44" for max reach over of 25" <i>Side unobstructed</i> - 15" to 48" (max 10" over object); <i>side high obstructed</i> - 46" for max of 24" over object; EXC - 36" to top of washer/dryers; 54" to fuel dispensers (Safe harbor - existing RR - 9" to 54") | No | Yes | Yes | | No | Main: tstat at 59" (SC96), 59" to electrical box (SC113) Pantry: hooks at 70.5" (SC115) |
| 309.4 | Are operable parts usable w/out a tight pinch or grasp? (ie: windows, switches) | No | Yes | Yes | | Yes | Main: electrical box by men's (SC113) |
| 702.1 | If an alarm exists in public room is it a visual/audible alarm? (excluding closets) | n/a | n/a | n/a | | n/a | |
| 701.1 | If an employee space, is the room within hearing distance of an audible alarm? (n/a for 1991) | n/a | n/a | n/a | | n/a | |
| 226.1 | Is there a portion of any work surface that is 30" w and 34" high with knee and toe clearance? (public spaces only) | Yes | n/a | n/a | | n/a | |
| 606.3 | If there is a sink, is it of compliant height of 34" w/CFS? (does not apply to mop basins, utility sinks, or bar sinks) | No | n/a | n/a | | n/a | Main: single drinking fountain (SC105) |
| OTHER: | | | | | | | |

| | Rooms/Spaces: E = denotes employee space P=public | fl#: P library | fl#: P shop | fl#: P/E | fl#: P/E | fl#: P/E | Notes: E = employee; P = public |
|--------------------|--|-------------------|----------------|----------|----------|----------|--|
| 403.5.1 | Is there a 36" wide access aisle to move freely about the room and to all aspects of the room/space? (can reduce to 32" for a max of 24" if there is CFS on either side) | Yes | Yes | | | | |
| 307.4 | Is there at least 80" vertical head space along the accessible route? | Yes | Yes | | | | |
| 304.3.1 304.3.2 | Are there sections of the route that are 60" wide and allowing for turning or T shaped? (60" square w/36" arms) | Yes | Yes | | | | |
| 307.2 | Is the room free of protruding objects? (nothing greater than 4" between 27"-80" aff) (handrails can protrude 4.5") | No | Yes | | | | Library: 12.5" shelf (SC116 , SC117) |
| 302.1 | Are the floor surfaces of the room/space firm, stable and slip resistant? | Yes | Yes | | | | |

CITE ELEMENT: ROOMS/SPACES Yes/No/n/a

| | | | | | | | |
|----------------|---|-----|-----|--|--|--|---|
| 302.2 | If carpeted, are edges securely fastened, and pile < .5" | Yes | Yes | | | | |
| 303.2 303.3 | Are CIL .25" max? If CIL is between .25" and .5" is beveled w/max slope 1:2? | n/a | n/a | | | | |
| 303.4 | Where there are changes in level greater than .5" is there a ramp provided that has a slope no greater than 1:12? | n/a | n/a | | | | |
| 302.3 | Are any gaps in the floor .5" or less? (.5" elongated gaps must be perpendicular to path of travel) | n/a | n/a | | | | |
| 403.3 | Is the slope of the floor surface no greater than 5% running or 2.08% cross and surface firm, stable and slip resistant? | Yes | Yes | | | | |
| 305.3 | Is there clear floor space around fixtures and operable parts? (30" by 48") | No | Yes | | | | Library: table in CFS of book shelf at 24.5" (SC118 , SC119); tstat in middle of book case (SC120); light switch behind cabinet (SC121) |
| 308 | Is at least one of each type of operable parts within reach range? (ie: windows) <i>Forward unobstructed</i> - 15" to 48" (max 20" over object); <i>forward high obstructed</i> - max 44" for max reach over of 25" <i>Side unobstructed</i> - 15" to 48" (max 10" over object); <i>side high obstructed</i> - 46" for max of 24" over object; EXC - 36" to top of washer/dryers; 54" to fuel dispensers (Safe harbor - existing RR - 9" to 54") | No | Yes | | | | Library: tstat at 56" (SC120) |
| 309.4 | Are operable parts usable w/out a tight pinch or grasp? (ie: windows, switches) | Yes | Yes | | | | |
| 702.1 | If an alarm exists in public room is it a visual/audible alarm? (excluding closets) | n/a | n/a | | | | |
| 701.1 | If an employee space, is the room within hearing distance of an audible alarm? (n/a for 1991) | n/a | n/a | | | | |
| 226.1 | Is there a portion of any work surface that is 30" w and 34" high with knee and toe clearance? (public spaces only) | Yes | No | | | | Shop: 43" counter (SC123 , SC134) |
| 606.3 | If there is a sink, is it of compliant height of 34" w/CFS? (does not apply to mop basins, utility sinks, or bar sinks) | n/a | n/a | | | | |

Rev. 04/21/14