

MULTIPLE DOORS CHECKLIST

Cite:	Question:	Door: E Door #: Admin entry	Door: I Door #: Office near entry	Door: I Door #: Office behind recp	Door: I Door #: Furnace	Door: I Door #: Lab	Door: I Door #: Certified lab	Door: E Door #: Lab exit	Door: I Door #: Cert lab office	Door: I Door #: Bacteriology
	If a double door, measure only the active leaf									
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: trash can on pull (WW1)	No: storage on pull	No: desk and chair on pull (WW2 , WW3)	No: storage prevent from open to 90 (WW4)	No: fire extinguish er (WW5)	Yes	Yes	No: desk and garbage on pull (WW10)	Yes
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	Yes	Yes	No: 3.4% (WW6 , WW7)	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	Yes	Yes	Yes	n/a	n/a	n/a	No: 2" (WW8)	Yes	n/a
404.2.5	Thresholds < 1/2 "	Yes	n/a	n/a	n/a	n/a	n/a	Yes	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	No	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	Yes	Yes	n/a	n/a	n/a	n/a	Yes	n/a
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	No	No	n/a	n/a	n/a
11B- 404.2.7	Hardware height (34"-	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

	44")									
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 12#	n/a	n/a	n/a	n/a	n/a	Yes	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	n/a	n/a	n/a	n/a	n/a	Yes	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	Yes	n/a	Yes	n/a	Yes	Yes	Yes	n/a	Yes
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

	both sides?									
Other:										

Rev. 04/21/14

Cite:	Question:	Door: I Door #: Corner lab	Door: I Door #: Back storage	Door: E Door #: Back exit	Door: E Door #: Exit from back storage	Door: I Door #: Men's RR	Door: I Door #: Women's RR	Door: I Door #: Men's LR	Door: I Door #: Front storage	Door: I Door #: Women's LR
	If a double door, measure only the active leaf									
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	No: storage on pull (WW12)	No: 11" to wall on push (WW13)	No: bike and fridge back (WW15)	No: laundry on pull (WW155)	Yes	Yes	No: file cabinet back on pull (WW16)	Yes
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	n/a	n/a	Yes	Yes	Yes	Yes	n/a	n/a	Yes
404.2.5	Thresholds < 1/2 "	n/a	n/a	Yes	Yes	n/a	n/a	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes

Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	No: 8#	No: 11#	n/a	n/a	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	n/a	No	Yes	n/a	n/a	n/a	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	Yes	n/a	Yes	Yes	n/a	n/a	n/a	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a								
Other:										

Cite:	Question:	Door: E Door #: Front exit	Door: E Door #: FES power building	Door: E Door #: FEC MCC	Door: E Door #: blower	Door: E Door #: Blower building	Door: E Door #: Blower building door 2	Door: E Door #: Old storage	Door: E Door #: MCC pump room from storage	Door: E Door #: MCC pump room front
If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	No: equip int (WW17)	No: recessed	No: recessed	Yes	Yes	No: storage (WW28)	Yes	Yes
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes	Yes	Yes	No: 6.4% (WW22 , WW23)	No: 7.9% (WW25 , WW26)	No: 18.1% (WW29 , WW30)	No: 5.4% (WW31 , WW32)	No: 2.8% (WW34 , WW35)
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	No: 25.5" (WW27)	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	No	No	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	Yes	Yes	Yes	Yes	Yes	Yes	n/a	No: 2" (WW33)	No: 1.5" (WW36)
404.2.5	Thresholds < 1/2 "	Yes	Yes	Yes	Yes	Yes	Yes	n/a	Yes	Yes
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	Yes	n/a	n/a	n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
302.3	If openings in floor,	n/a	n/a	n/a	n/a	No: 1.25"	n/a	n/a	n/a	n/a

	≤1/2" and perpendicular					(WW24)				
309.4; 404.2.7	Door hardware compliant?	No: knob	No: knob (WW18)	No: knob	No: knob	No: knob	No: knob	No: knob	No: knob	No: knob
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 14#	No: 10#	No: 10#	No: 10#	No: 9#	No: 7#	n/a	No: 13#	No: 14#
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	No	No	No	No	No	n/a	Yes	Yes
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	Yes	n/a	n/a	n/a	n/a	n/a	n/a	n/a	Yes
404.2.8.2	For spring hinges – closer 1.5 sec. from 70	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

	to close									
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a								
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a								
Other:										

Cite:	Question:	Door: E Door #: Generator bldg.nr pump	Door: E Door #: Generator bldg. near front	Door: E Door #: Sodium chl storage	Door: I Door #: Pump room nxt to SC	Door: E Door #: Pump room far side	Door #: E Chlorine pump room	Door: E Door #: Filter plant	Door: I Door #: PACL to 2 nd room	Door: I Door #: Filter room 2 nd to 3 rd room
	If a double door, measure only the active leaf									
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	Yes	No: tank, fire ext (WW44)	No: wall on push (WW49)	No: table back on push	Yes	No: steps (WW54)	Yes	No: cabinet on pull (WW61)
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	No: 5.8% (WW38 , WW40)	No: 3.6% (WW41 , WW42)	No: 2.8% (WW46 , WW47)	n/a	Yes	Yes	No: 13.4% slope on approach (WW55 , WW56)	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	Yes	No: 1.5" (WW43)	No: 1.5" (WW45)	No: 1.5" (WW48)	No: 2" (WW50)	No: 1.5" (WW51)	No: 1.75" (WW58)	Yes	Yes

	for view have at least one panel max 43" aff? (exc. if bottom above 66")								(WW60)	
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a							
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a							
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a							
Other:										

Cite:	Question:	Door: E Door #: Filter blower exit	Door: E Door #: Plant mtncce	Door: E Door #: Back exit from shop	Door: E Door #: Press building front	Door: E Door #: Press building back	Door: E Door #: Mech building	Door: I Door #: RR/storage	Door: I Door #: Office to shop	Door: I/E Door #:
If a double door, measure only the active leaf										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: trailer on push (WW62)	Yes	No: storage (WW67)	Yes	Yes	No: storage on push (WW72)	No: shelf on pull, storage on push (WW73 , WW74)	No: water cooler and desk on pull (WW225)	
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	No: 8% (WW125 , WW63)	Yes	Yes	No: 2.8% (WW69 , WW70)	Yes	No: 3.6% (WW71 , WW72)	Yes	Yes	
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	

404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
303.2	Change in level < 1/4"	No: 1.75" (WW64)	Yes	Yes	Yes	Yes	Yes	n/a	n/a	
404.2.5	Thresholds < 1/2 "	Yes	Yes	Yes	Yes	Yes	Yes	n/a	n/a	
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
302.2	If carpeted is pile < 1/2"	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	No: .75" (WW68)	n/a	n/a	n/a	n/a	n/a	
309.4; 404.2.7	Door hardware compliant?	Yes	No: knob (WW66)	No: knob	No: knob	No: knob	No: knob	No: knob	No: knob	
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 16#	n/a	n/a	No: 13#	No: 13#	No: 12#	n/a	n/a	
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	n/a	n/a	No	Yes	No	n/a	n/a	

404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	No: 46.5" (WW65)	Yes	n/a	Yes	Yes	Yes	n/a	Yes	
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
Other:										