

CITE **ELEMENT: STAIRS** Yes/No/n/a

	Stairs:	1: pump room I	Notes:
210.1	Is the stairway part of a means of egress? (if yes, apply full checklist)	No	
210.1	Is the stairway between floors that are connected by an accessible route? (If yes, only handrail requirements apply when stairs are altered; skip to handrail section)	No	
504.2	Are risers on stairs 4"-7" high and uniform?	Yes	
504.2	Are the treads 11" deep minimum and uniform?	No	9.5"-10" (WW239 , WW240)
504.3	Are all risers closed?	Yes	
504.4/302.1	Is floor/ground surface stable, firm, and slip-resistant?	Yes	
302.2	If carpet, is it securely fastened and pile < .5"?	n/a	
302.3	If the treads have openings, are they less than .5" and perpendicular to direction of travel?	n/a	
504.5	Are the nosings on stairs curved or beveled at .5" radius? (It's a benefit to have contrasting colors on the nosings, but not required)	Yes	
504.5	Do nosings project max 1.5" over tread below?	n/a	
504.7	<i>For exterior stairs</i> , are stairways and landings designed to prevent water accumulation?	n/a	
504.4 (advisory)	Does the top stair have a detectable warning at the top of the stair run?	No	
11B-504.4.1	Is the upper approach and lower tread marked with a stripe in a contrasting color? (int) Is the upper approach and all treads marking with a stripe in a contrasting color? (ext) <i>(Stripe should be 2"-4" wide and not more than 1" from nose.)</i>	Yes	
11B-504.8	Are floor identification signs provided at the landing of each floor level, mounted adjacent to door on latch side?	n/a	
505.2	Handrails: (505) Do all stairs have handrails on both sides? (ONLY ASSEMBLY AREAS DO NOT REQUIRE HAND RAILS ON BOTH SIDES)	No	(WW241)

CITE **ELEMENT: STAIRS** Yes/No/n/a

505.3	Are all handrails continuous?	Yes	
505.3	On doglegs/switchbacks is the inside rail continuous?	n/a	
505.10.3	At the bottom of the stairway, do the handrails extend at the slope of the stair flight for a distance equal to one tread depth? (in alterations, it can turn at 90 degrees if presenting a hazard)	No	(WW241)
505.10.2	Do the handrails horizontally extend to a point 12" beyond the top riser nosing?	No	Only one side (WW237)
505.4	Is the top of the gripping surface 34"-38" max high from the walking surface?	Yes	
505.5	Is there a clearance of 1.5" min between the handrail and the adjacent surface?	n/a	
505.6	Gripping surfaces shall be uninterrupted by newel posts, other construction elements, or obstructions on the top or side. Bottom of gripping surface shall be obstructed for no longer than 20% of its length.	Yes	
505.6	Where provided, are horizontal projections 1.5" minimum below the bottom of the handrail gripping surface?	n/a	
505.7.1	Is the gripping surface 1.25" – 2" in diameter, or a non circular grip that has a perimeter dimension of 4"- 6.25" max?	Yes	
505.8	Are handrail edges free of sharp edges and abrasive elements?	Yes	
505.9	Are handrails secure in their fittings? (don't rotate)	Yes	
505.4	If <i>Children</i> are the primary users: second set of handrails with a min 9" between them and the higher set? Is the lower set 28" max from the walking surface? (best practice)	n/a	
307.4	Is there 80" vertical clearance along the stairway?	Yes	

Rev. 07/31/13