Building/Site: Hocus Pocus Park Team: Shelley Zuniga, Dana Esposito
Date: 11/11/15 Job#: R15025

Cite Element: Park Site Yes No n/a Notes:

Element: (ball field, etc)	How many of each element at this site?	Is it designed for wheelchair use? (i.e.: surface, reach range, etc, see notes)	AR to element?	Does the AR extend to play surface/both sides of sport court?	Does the AR extend to player seating?	Does the AR extend to spectator seating?	Designated entry 32" for doorway/gate, 36" for entry w/o door with maneuvering clearance?	total accessible/ total (ex - 0/5)	Notes: *RR: Forward unobstructed* - 15" to 48" (max 20" over object) *forward high obstructed* - max 44" for max reach over of 25" over 34" aff counter *Side unobstructed* - 15" to 48" (max 10" over object) *side high obstructed* - 46" for max of 24" over object (Safe harbor - existing RR - 9" to 54")
1. basketball	1	Yes	Yes	No	Yes	n/a	n/a	0/1	Grass at entry (HP29)
2. garbage	4	Yes	Yes	n/a	n/a	n/a	n/a	4/4	
3. drinking fountain	1	Yes	Yes	n/a	n/a	n/a	n/a	0/1	Not high low (HP20)
4. bike racks	2	n/a	Yes	n/a	n/a	n/a	n/a	2/2	4.5% slope in CFS (HP32, HP33)

	Benches:				How many: 5 How many accessible: 2
1011.2.1	Is there clear floor space adjacent to the bench for wheelchair position?		X		
Smart practice	Is the seat height 17" to 19" above the ground?		X		16" both w/ CFS (HP18, HP19)
Smart practice	Is there a back support that extends the full length of the bench seat?		X		
Smart practice	Is there an armrest on at least one side?		X		
F245	Are at least 20% of benches accessible?	X			
	Picnic Tables:				How many: n/a (see shelters) How many accessible:

Rev: 04/9/2014

Property of Recreation Accessibility Consultants, LLC.