

CITE                    **ELEMENT: SHELTERS/PICNIC AREAS**

|                  | Questions  | Shelter: covered by play area                   | Picnic Area: near RR                          | Picnic Area: near basketball |
|------------------|--|---|---|------------------------------|
|                  | If the route includes a ramp, refer to means of access checklist   | n/a   | n/a   | n/a                          |
| F245             | If benches exist along the accessible route, are at least 20% or no less than 2 accessible? (best practice)                                | Yes   | n/a   | n/a                          |
| F245             | Are 20% of picnic tables accessible? (best practice)   | Yes: 1/3  | No: 0/1 ( <a href="#">HP23</a> )              | 1/1                          |
| 401-403          | Is there accessible entry into covered area or an AR to the picnic area?   | Yes   | Yes   | Yes                          |
| 302.3            | Are all gaps <.5"?   | Yes   | n/a   | Yes                          |
| 303.2            | Are all changes in level <.25"?  | Yes   | n/a   | n/a                          |
| 304.3.1, 304.3.2 | Is there turning space of a circular 60" diameter min or a t-shaped turning space within a 60" square min with arms and base 36" wide min? | Yes   | n/a   | Yes                          |
| 206.2.2          | Is there an AR to all shelter/picnic amenities?  | Yes   | Yes   | Yes                          |
|                  | Are shelter/picnic amenities of an accessible design? (drinking fountain, hi-lo, grill in reach range, outlets in reach range, etc.)       | No: grill height 43.5" ( <a href="#">HP22</a> ) | No: grill height 35" ( <a href="#">HP24</a> ) | Yes                          |
| 308              | Are operable parts of unique features w/in reach range?  | n/a   | n/a   | n/a                          |
| 307.2            | Are all protrusions into the general circulation path <4"?   | n/a   | n/a   | n/a                          |
| 307.4            | Is there 80" min overhead clearance?   | Yes   | n/a   | n/a                          |
|                  | <b>Portable Toilets:</b><br>If a portable toilet is provided, refer to single user checklist   | n/a   | n/a   | n/a                          |

Rev. 07/31/13