

**MULTIPLE DOORS CHECKLIST**

Cite:	Question:	Door: E Door #: Women's RR	Door: E Door #: Men's RR
<b>If a double door, measure only the active leaf</b>			
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	Yes	Yes
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a
303.2	Change in level < 1/4"	n/a	n/a
404.2.5	Thresholds < 1/2 "	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	n/a
302.3	If openings in floor, ≤1/2" and perpendicular	Yes	Yes
309.4; 404.2.7	Door hardware compliant?	Yes	Yes
Smart practice	Hazardous areas knurled handle	n/a	n/a
11B- 404.2.7	Hardware height (34"-44")	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a
11B- 404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a
11B- 404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	No: 11#	No: 8#
404.2.8	Door closers: 3 sec. from 70 to 3"	Yes	Yes
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	n/a

Building/Site: Hocus Pocus Park  
Date: 11/11/15

Team: Shelley Zuniga, Dana Esposito  
Job#: R15025

404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a
Other:			

Rev. 04/21/14