

Building/Year built: Lodato Park
 Date: 11/11/15
 Cite Element: Park Site

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

Yes No n/a Notes:

Element: (ball field, etc)	How many of each element at this site?	Is it designed for wheelchair use? (i.e.: surface, reach range, etc, see notes)	AR to element?	Does the AR extend to play surface/both sides of sport court?	Does the AR extend to player seating?	Does the AR extend to spectator seating?	Designated entry 32" for doorway/gate, 36" for entry w/o door with maneuvering clearance?	total accessible/ total (ex - 0/5)	Notes: <i>RR: Forward unobstructed - 15" to 48" (max 20" over object) forward high obstructed - max 44" for max reach over of 25" over 34" aff counter Side unobstructed - 15" to 48" (max 10" over object) side high obstructed - 46" for max of 24" over object (Safe harbor - existing RR - 9" to 54")</i>
1. garbage can	1	Yes	Yes	n/a	n/a	n/a	n/a	1/1	(LP5)
2. dog waste bag	1	Yes	No	n/a	n/a	n/a	n/a	0/1	(LP11)
3. bike rack	1	Yes	No	n/a	n/a	n/a	n/a	0/1	(LP10)

	Benches:					How many: 0 How many accessible:
	Picnic Tables:					How many: 0 How many accessible:

Rev: 04/9/2014