

Cite Element: Park Site Yes No n/a Notes:

| Element: (ball field, etc) | How many of each element at this site? | Is it designed for wheelchair use? (i.e.: surface, reach range, etc, see notes) | AR to element? | Does the AR extend to play surface/both sides of sport court? | Does the AR extend to player seating? | Does the AR extend to spectator seating? | Designated entry 32" for doorway/gate, 36" for entry w/o door with maneuvering clearance? | total accessible/ total (ex - 0/5) | Notes: |
|-------------------------------|--|---|----------------|---|---------------------------------------|--|---|------------------------------------|---|
| 1. garbage can | 10 | Yes | Yes | n/a | n/a | n/a | n/a | 6/10 | RR: Forward unobstructed - 15" to 48" (max 20" over object) forward high obstructed - max 44" for max reach over of 25" over 34" aff counter Side unobstructed - 15" to 48" (max 10" over object) side high obstructed - 46" for max of 24" over object (Safe harbor - existing RR - 9" to 54") |
| 2. bike rack | 2 | Yes | No | n/a | n/a | n/a | n/a | 0/2 | Lacks AR (MP47) |
| 3. grill counter | 1 | No | Yes | n/a | n/a | n/a | n/a | 0/1 | 37" counter; 38" to grill; 35" to sink w/ knobs (MP51 , MP52) |
| 4.horseshoes | 1 | Yes | No | n/a | n/a | n/a | n/a | 0/1 | |
| 5. Drinking fountain | 1 | No | Yes | n/a | n/an | n/a | n/a | 0/1 | Single bowl (MP53) |

| | Benches: | | | | How many: 2 How many accessible: 0 |
|----------------|---|---|---|--|--|
| 1011.2.1 | Is there clear floor space adjacent to the bench for wheelchair position? | | X | | (MP45) |
| Smart practice | Is the seat height 17" to 19" above the ground? | | X | | (MP50) |
| Smart practice | Is there a back support that extends the full length of the bench seat? | X | | | |
| Smart practice | Is there an armrest on at least one side? | | X | | |
| F245 | Are at least 20% of benches accessible? | | X | | |
| | Picnic Tables: | | | | How many: 5 How many accessible: 1 |
| F245 | Do picnic tables comply with 1011? | X | | | Lacks AR to element (MP54) |

Building/Year built: MacDorsa Park/Scott House
 Date: 11/10/2015

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

Cite Element: Park Site Yes No n/a Notes:

| | | | | | |
|----------------------|---|---|---|--|--|
| | | | | | |
| 1011.4 | Does each accessible picnic table provide at least one wheelchair space with knee space 27" high, 30" wide and 9" deep? | | X | | |
| 1011.4 | Does the wheelchair space have toe clearance 9" high minimum and that extends 17" min and 25" max deep? | X | | | |
| 1011.2.1 | Is there 36" minimum clear space provided around the usable portion of table? (measured from the back edge of the seat) | | X | | |
| 1011.2.2 1011.3.3 | Is the surface of the clear space firm and stable with max slope 2.08% in all directions? | X | | | |

Rev: 04/9/2014