

CITE **ELEMENT: SHELTERS/PICNIC AREAS**

	Questions	Shelter/Picnic Area:
	If the route includes a ramp, refer to means of access checklist	n/a
F245	If benches exist along the accessible route, are at least 20% or no less than 2 accessible? (best practice)	n/a
F245	Are 20% of picnic tables accessible? (best practice)	Yes
401-403	Is there accessible entry into covered area or an AR to the picnic area?	No (MP84)
302.3	Are all gaps <.5"?	Yes
303.2	Are all changes in level <.25"?	Large step to entry (MP81)
304.3.1, 304.3.2	Is there turning space of a circular 60" diameter min or a t-shaped turning space within a 60" square min with arms and base 36" wide min?	No, picnic table (MP84)
206.2.2	Is there an AR to all shelter/picnic amenities?	No
	Are shelter/picnic amenities of an accessible design? (drinking fountain, hi-lo, grill in reach range, outlets in reach range, etc.)	n/a
308	Are operable parts of unique features w/in reach range?	n/a
307.2	Are all protrusions into the general circulation path <4"?	n/a
307.4	Is there 80" min overhead clearance?	Yes
	Portable Toilets: If a portable toilet is provided, refer to single user checklist	n/a

Rev. 07/31/13