

MULTIPLE DOORS CHECKLIST

| Cite: | Question: | Door: E Door #: back Entry | Door: E Door #: Porch entry | Door: I Door #: kitchen to dining | Door: I Door #: Dining to foyer | Door: E Door #: front door | Door: I Door #: foyer to parlor | Door: I Door #: dining to bedroom | Door: I Door #: Bedroom to pantry | Door: E Door #: bathroom from outside |
|---|---|------------------------------------|-----------------------------------|--|--|---|--|--|--|--|
| If a double door, measure only the active leaf | | | | | | | | | | |
| 404.2.4 404.2.4.1 404.2.4.2 | Maneuvering clr. around doors/entries | No, antique on pull (MP2) | No, storage on pull (MP7) | No, buffet on pull (MP13) | No, dining table on pull | No, pull side 13" to wall, stairs to door (MP15) | No, chair on pull (MP20) | No, dresser on pull (MP22) | No, counter on pull (MP28) | No entry/locke d |
| 404.2.4.4 | Do floor surfaces in MC comply with 302 (slope, CIL, gaps)? | Yes | 5.0% on push (MP8, MP9) | Yes | Yes | 3.3% (MP18, MP19) | Yes | Yes | Yes | |
| 307.4 | 80" Head Clearance (excl. closer; min 78") | Yes | 77.5" (MP10) | Yes | Yes | Yes | Yes | Yes | 77" (MP25) | |
| 404.2.3 | Door width 32"; with no projections > 4" between 34" and 80"? | 30" (MP3) | 30" | 27.5" (MP14) | 27.5" | 31" (MP17) | 27.5" | 30.5" (MP21) | 24.5" (MP24) | |
| 404.2.3 | If door is 24" D, is it 36" W | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | |
| 303.2 | Change in level < 1/4" | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | |
| 404.2.5 | Thresholds < 1/2 " | 1.5" (MP4) | 2" (MP11, MP12) | n/a | n/a | n/a | n/a | 1.25" | 1.25" | |
| 404.2.5 | If existing threshold is 3/4" is it beveled at 1:2? (exception) | No (MP6) | No | n/a | n/a | n/a | n/a | No | No | |
| 302.2 | If carpeted is pile < 1/2" | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | |
| 302.3 | If openings in floor, ≤1/2" and perpendicular | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | |

| | | | | | | | | | | |
|-------------------|---|------|------|------|------|------|------|--|--------------------|--|
| 309.4; 404.2.7 | Door hardware compliant? | Knob | Knob | Knob | Knob | Knob | knob | Pinch and small hardware (MP26) | Pinch small handle | |
| Smart practice | Hazardous areas knurled handle | n/a | n/a | |
| 11B-404.2.7 | Hardware height (34"-44") | Yes | Yes | |
| 404.3.5 | Is the CFS at the power door controls located outside of any door swing? | n/a | n/a | |
| 11B-404.3.5 | Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff? | n/a | n/a | |
| 404.2.9 | Pull Force; int. hinged doors; sliding or folding doors (5 lbf) | n/a | n/a | |
| 11B-404.2.9 | Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist | n/a | n/a | |
| 404.2.8 | Door closers: 3 sec. from 70 to 3" | n/a | n/a | |
| 404.2.10 | Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max) | n/a | n/a | |
| 404.2.11 | Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66") | n/a | n/a | n/a | n/a | Yes | n/a | n/a | n/a | |
| 404.2.8.2 | For spring hinges – | n/a | n/a | |

| | | | | | | | | | | |
|---------|---|-----|-----|-----|-----|-----|-----|-----|-----|--|
| | closer 1.5 sec. from 70 to close | | | | | | | | | |
| 404.2.6 | Series of doors clearance (48" clear width, doors open) | n/a | |
| 404.2.7 | Sliding doors hardware usable without tight pinch or grasp and on both sides? | n/a | |

| Cite: | Question: | Door: E Door #: W RR | Door: E Door #: M RR | Door: E Door #: Outside storage by RR | Door: I/E Door #: |
|-----------------------------------|---|----------------------------|----------------------------|---|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| 404.2.4 404.2.4.1 404.2.4.2 | Maneuvering clr. around doors/entries | No, push recessed (MP30) | No, recessed (MP31) | No entry, storage (MP1) | | | | | | |
| 404.2.4.4 | Do floor surfaces in MC comply with 302 (slope, CIL, gaps)? | Yes | Yes | Yes | | | | | | |
| 307.4 | 80" Head Clearance (excl. closer; min 78") | Yes | Yes | Yes | | | | | | |
| 404.2.3 | Door width 32"; with no projections > 4" between 34" and 80"? | Yes | Yes | No | | | | | | |
| 404.2.3 | If door is 24" D, is it 36" W | No, 32" wide | No, 32" wide | n/a | | | | | | |
| 303.2 | Change in level < 1/4" | Yes | Yes | Yes | | | | | | |
| 404.2.5 | Thresholds < 1/2 " | Yes | Yes | Yes | | | | | | |
| 404.2.5 | If existing threshold is 3/4" is it beveled at 1:2? (exception) | Yes | Yes | n/a | | | | | | |
| 302.2 | If carpeted is pile < 1/2" | n/a | n/a | n/a | | | | | | |
| 302.3 | If openings in floor, | n/a | n/a | n/a | | | | | | |

| | | | | | | | | | | |
|-------------------|---|-------|-------|-------|--|--|--|--|--|--|
| | ≤1/2" and perpendicular | | | | | | | | | |
| 309.4; 404.2.7 | Door hardware compliant? | knobs | Knobs | Knobs | | | | | | |
| Smart practice | Hazardous areas knurled handle | n/a | n/a | n/a | | | | | | |
| 11B- 404.2.7 | Hardware height (34"-44") | Yes | Yes | Yes | | | | | | |
| 404.3.5 | Is the CFS at the power door controls located outside of any door swing? | n/a | n/a | n/a | | | | | | |
| 11B- 404.3.5 | Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff? | n/a | n/a | n/a | | | | | | |
| 404.2.9 | Pull Force; int. hinged doors; sliding or folding doors (5 lbf) | n/a | n/a | n/a | | | | | | |
| 11B- 404.2.9 | Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist | 6# | 7# | n/a | | | | | | |
| 404.2.8 | Door closers: 3 sec. from 70 to 3" | Yes | Yes | n/a | | | | | | |
| 404.2.10 | Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max) | n/a | n/a | n/a | | | | | | |
| 404.2.11 | Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66") | n/a | n/a | n/a | | | | | | |
| 404.2.8.2 | For spring hinges – closer 1.5 sec. from 70 to close | n/a | n/a | n/a | | | | | | |

Building/Year built: MacDorsa Park/Scotts House
Date: 11/10/2015

Team: Shelley Zuniga, Dana Esposito
Job#: R15025

| | | | | | | | | | | |
|---------|---|-----|-----|-----|--|--|--|--|--|--|
| 404.2.6 | Series of doors clearance (48" clear width, doors open) | n/a | n/a | n/a | | | | | | |
| 404.2.7 | Sliding doors hardware usable without tight pinch or grasp and on both sides? | n/a | n/a | n/a | | | | | | |