

Cite Element: Park Site Yes No n/a Notes:

Element: (ball field, etc)	How many of each element at this site?	Is it designed for wheelchair use? (i.e.: surface, reach range, etc, see notes)	AR to element?	Does the AR extend to play surface/both sides of sport court?	Does the AR extend to player seating?	Does the AR extend to spectator seating?	Designated entry 32" for doorway/gate, 36" for entry w/o door with maneuvering clearance?	total accessible/total (ex - 0/5)	Notes:
1. Dog park	2	Yes	No	n/a	n/a	n/a	n/a	0/2	RR: Forward unobstructed - 15" to 48" (max 20" over object) forward high obstructed - max 44" for max reach over of 25" over 34" aff counter Side unobstructed - 15" to 48" (max 10" over object) side high obstructed - 46" for max of 24" over object (Safe harbor - existing RR - 9" to 54")
2. Information sign	1	Yes	No	n/a	n/a	n/a	n/a	0/1	AR is loose gravel/dirt; Latch at 51" (SDP2, SDP3) reach over gate; unable to enter large dog park due to dirt at gate (SDP7); tables and chairs in mulch (SDP8, SDP9, SDP12); water spigot not on AR in both (SDP10) (SDP5)

	Benches:					How many: 0 How many accessible:
	Picnic Tables:					How many: 0 How many accessible:

Rev: 04/9/2014