

CITE	ELEMENT: PARKING	YES	NO	n/a	NOTES												
208.2	<p>Parking Spaces: Parking Lots and Parking Structures are required to provide a minimum number of accessible parking spaces located on an accessible route and as close as possible to the accessible building entrance. If there are multiple parking areas, the required numbers of accessible parking spaces are based on each individual lot.</p> <p>*Does the lot meet the minimum number of accessible parking spaces per chart below?</p> <table border="0"> <tr> <td>1 to 25: 1</td> <td>151 to 200: 6</td> </tr> <tr> <td>26 to 50: 2</td> <td>201 to 300: 7</td> </tr> <tr> <td>51 to 75: 3</td> <td>301 to 400: 8</td> </tr> <tr> <td>76 to 100: 4</td> <td>401 to 500: 9</td> </tr> <tr> <td>101 to 150: 5</td> <td>501 to 1000: 2% of total</td> </tr> <tr> <td>1001 and over: 20, plus 1 for each 100, or fraction thereof, over 1000</td> <td></td> </tr> </table> <p>For every 6 accessible parking spaces, there must be 1 van accessible spot.</p>	1 to 25: 1	151 to 200: 6	26 to 50: 2	201 to 300: 7	51 to 75: 3	301 to 400: 8	76 to 100: 4	401 to 500: 9	101 to 150: 5	501 to 1000: 2% of total	1001 and over: 20, plus 1 for each 100, or fraction thereof, over 1000		X			<p>Total # of standard spaces: 60</p> <p>Total # of accessible spaces: 3</p>
1 to 25: 1	151 to 200: 6																
26 to 50: 2	201 to 300: 7																
51 to 75: 3	301 to 400: 8																
76 to 100: 4	401 to 500: 9																
101 to 150: 5	501 to 1000: 2% of total																
1001 and over: 20, plus 1 for each 100, or fraction thereof, over 1000																	
208.3.1	<p>Are the spaces located on the Shortest Accessible Route from the accessible parking space to an accessible entrance?</p> <p>(Dispersion: where parking serves more than one accessible entrance, disperse the accessible parking spaces so located on the shortest accessible route to each entrance.)</p>	X															
502	The space:																
11B-502.2	Is the vehicular space 216" (18') long, 108" (9 feet) wide, and is the access aisle 60" (5 feet) wide and extend the full length of the space?		X		Stalls ok, no AA (SDP13)												
11B-502.3.3	Are access aisles marked with a blue painted border around the perimeter and the area within marked with diagonal lines spaced 36" on center in a contrasting color to the surface (preferred blue or white) and having the words NO PARKING painted in white on aisle, min of 12" high			X													
11B-502.6.4	Is the stall painted in blue paint (or suitable contrast) and designated with the symbol of access (white icon on blue background) 36" X 36" big and centered on space?		X		(SDP14)												
502.2	Is there at least one van parking space (12 feet wide with a 5 foot wide access aisle located on the passenger side OR 9' and 8')?		X														

CITE	ELEMENT: PARKING	YES	NO	n/a	NOTES
502.5	Is there 98" of vertical clearance for van designated parking at the space and from parking entry to the space?			X	
502.4	Is the slope in the stall or access aisle no greater than 1:48 in any direction? (2.08%)	X			
502.3.4	Are all of the access aisles clear of the vehicular way? (doesn't overlap vehicular way)			X	
502.4	Is the parking stall and access aisle compliant with 302; (CIL, gaps, surface firm, stable and slip resistant)?	X			
502.6 11B-502.6.2	Is there a compliant sign for the accessible parking/van space(s) with the international symbol of accessibility, and Violation Sign stating a \$250.00? (exempt if 4 or less parking spaces; 216.5, exc. 1)		X		(SDP15)
502.6	Is the bottom edge of the lowest sign 60" agl, measured from the parking surface; or 80" if in the EAR?		X		(SDP15)
11B-502.6.1	Is signage reflectorized and have a min area of 70"?	X			
208.2.4	Is there a van accessible sign on at least one space?		X		
11B-502.8	Is there additional signage posted conspicuously stating: <i>"Unauthorized vehicles parked in designated accessible spaces not displaying distinguishing placards or special license plates issued for persons with disabilities will be towed away at the owner's expense. Towed vehicles may be reclaimed at: _____ or by telephoning _____."</i>		X		
502.3	Do the Access Aisles connect the accessible parking space to an accessible entrance? (Access Aisles can be located on either side of the vehicle, except for angled parking, then it must be on the passenger side.)		X		CIL to wood mulch or gravel (SDP17)
502.7 11B-502.7.1	Are parking spaces/access aisles designed so that cars and vans, when parked, cannot obstruct the required CW of adjacent accessible routes Are wheel stops provided to prevent cars overhanging into AR?		X		

Rev. 04/9/14