

| Cite | Element: Playground | Yes | No | n/a | Notes: |
|----------------|---|-----|----|-----|---|
| | Scoping: | | | | |
| 206.2.1 | Does a firm and stable route lead from the parking lot/street to all accessible entrances at the playground? | X | | | |
| Smart practice | Does the playground have a designated entrance to both elevated and ground level play components? (<i>best practice</i>) | X | | | |
| Smart practice | Is the designated entry 60" wide min with compliant changes in level, gaps, and slopes? | X | | | |
| 240 | Is there a posted age group of intended users of playground? (2-5, 5-12, 2-12, under 2, teens) | X | | | 5-12 |
| | If age group is not posted, list assumed age group(s) applied during audit | | | | |
| Smart practice | Do compliant signs exist at the playground? What type? (informational, directional) | X | | | |
| 206.2.2 | Is there an <i>intended</i> AR throughout the play area surface, connecting surface, ground level play components, and elevated play components? | X | | | |
| 206.2.2 | If the playground is greater than 1000 square feet, is there a 60" wide AR connecting entrance (if there is one) to accessible GLPC and accessible EPC? | X | | | |
| 1008.2.1.1 | If the playground is <1000 sq. ft is the AR 44" min, with a turning space every 30' min | | | X | |
| | Accessible Route w/in play area: (measure even if loose fill not determined) | | | | |
| 403.3 | Is the running slope no greater than 1:20? (5%) | | X | | Loose fill not compacted, various slopes throughout |
| 403.3 | Is the cross slope no greater than 1:48? (2.083%) | | X | | |
| 1008.2.4.1 | Is the clear width a min of 60" | X | | | |
| 1008.2.4.1 | If the AR is only 36" wide, is it no longer than 60"? | | | X | |

| Cite | Element: Playground | Yes | No | n/a | Notes: |
|----------------|--|-----|----|-----|--|
| 1008.2.4.2 | Is the elevated AR 36" wide minimum to ramp accessed EPC? | | | X | |
| 303.2 | Are all changes in level <1/4"? | X | | | |
| 1008.2 | Is there 80" of vertical clearance along the AR? | X | | | |
| | Does the AR connect to component egress point? | X | | | |
| | Play Area Surface: (refer to playground questionnaire) | | | | |
| 1008.2.6.1 | Describe evidence of maintenance/lack of | | | | |
| 1008.2.6 | Is the surface firm, stable, and maneuverable? (Made of EWF, PIP, hybrids, tiles, shredded rubber) <i>If uncertain, leave blank until verified</i> | X | | | EWF |
| | Transfer Systems | | | | |
| 1008.2 | Is TS connected to AR? | X | | | |
| 1008.3 | Is there more than one TS provided? (best practice for structures having more than 10 EPC's) | | | X | |
| 1008.3.1.2 | Is the height of the transfer platform 11" to 18" above surface? | | X | | 23" (STP151) |
| 1008.3.1.1 | Is the transfer platform 14" deep and 24" clear width minimum? | X | | | |
| 1008.3.1.3 | On the 24" side; Is there clear floor space centered and parallel of 30" X 48"? | X | | | |
| 1008.3.1.4 | Are there transfer supports provided? (holds, bars, mounds, etc.) | X | | | |
| 1008.3.2.1 | Are the steps connecting to TS platform 14" X 24"? | X | | | |
| 1008.3.2.2 | Is the rise of steps connecting to platform uniform and 8" max? | X | | | |
| 1008.3.2.3 | Are transfer supports provided on the steps? | X | | | |
| Smart practice | Is there a descending step? (best practice) | X | | | |
| | Ground to ground surface ramps: | | X | | 7.7% (STP149 , STP150) |
| 1008.2.5 | Is the slope no greater than 1:16? (6.25%) | | | | |

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

Cite Element: **Playground**

Yes No n/a Notes:

| | | | | | |
|-------------------------------|---|--|---|---|--|
| 1008.2.5.3.1 | Is there a handrail provided? (not required in <i>use zone</i>) | | X | | |
| 1008.2.5.3.1 | Is the handrail grip surface .95" to 1.55" max? | | | X | |
| 1008.2.5.3.2 | Is the handrail height 20" to 28" above the surface? | | | X | |
| | Ground to <i>elevated play area</i> ramps: | | | | |
| 1008.2.5.2 | Is the slope no greater than 1:12? (8.33%) | | | X | |
| 1008.2.5.2 | Is the max rise of ramp 12"? | | | X | |
| 1008.2.5.3.1 | Is there a handrail provided? (not required in <i>use zone</i>) | | | X | |
| 1008.2.5.3.1 | Is there 36" clear width between handrails? | | | X | |
| 1008.2.5.3.2 | Is the handrail grip surface .95" to 1.55" max? | | | X | |
| 1008.2.5.3.2 | Is the handrail height 20" to 28" above the surface? | | | X | |
| 405.7.1 405.7.2 405.7.3 | Is there a level landing of 60" X 36"? | | | X | |

USE THE FOLLOWING REACH RANGES WHEN AUDITING EPC's

Transferred to deck:

2-5: 2" to 24"
 5-12: 4" to 28"

For usability of interactive components such as talk tubes/periscopes for children transferring out of chairs, use the reach ranges of:

2-5: 12" to 20"
 5-12: 18" to 26"

Seated in w/c

2-5: 20" to 36"
 5-12: 16" to 44"

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

Cite Element: **Playground**

Yes No n/a Notes:

| 1008.4 1008.4.2 1008.4.5 | List all ELEVATED PLAY COMPONENTS | Reach range (Smart Practice for T) | On AR? | Accessed by Ramp (R) or transfer (T) or trans through component (TC) | 60" TS n/a if only accessed by TS | 30X48 CFS n/a if only accessed by TS | If transfer Or entry reqd., is there a means of support? | Compliant: +/- | Notes: If surface is not compliant, answers assume surface correction |
|--------------------------------|--|------------------------------------|--------|--|--------------------------------------|---|--|----------------|---|
| | 1. slide | n/a | Yes | T | n/a | n/a | Yes | + | |
| | 2.block steps | Yes | Yes | T | n/a | n/a | Yes | + | |
| | 3.sign language panel | No | Yes | T | n/a | n/a | n/a | - | 35" to top row (STP153 , STP154) |
| | 4.music panel | Yes | Yes | T | n/a | n/a | n/a | + | |
| | 5.arch climber | Yes | Yes | T | n/a | n/a | Yes | + | |
| | 6.tunnel | Yes | Yes | T | n/a | n/a | Yes | + | |
| | 7.chain ladder | Yes | Yes | TC | n/a | n/a | Yes | + | |
| | 8.U bar climber, arched | Yes | Yes | TC | n/a | n/a | Yes | + | |
| | 9.u bar ladder | Yes | Yes | TC | n/a | n/a | Yes | + | |
| | 10.sign lang panel | Yes | Yes | T | n/a | n/a | n/a | + | |
| | 11.steering wheel | Yes | Yes | T | n/a | n/a | n/a | + | |
| | 12.dlb slide | n/a | Yes | T | n/a | n/a | Yes | + | |
| | 13.tube slide | n/a | Yes | T | n/a | n/a | Yes | + | |
| | 14.shape panel | Yes | Yes | T | n/a | n/a | n/a | + | |
| 13 of 14 compliant | | | | | | | | | |
| 1008.2.1.1 | Elevated play components | | | | X | | | | |
| | If there are <20 EPC's: is there a transfer system that reaches 50% of EPC's? | | | | | | | | |
| 1008.2.1 | If there are >20 EPC's: Does a minimum of 25% EPC's connect by ramp, and 25% EPC's connect by transfer system? | | | | | x | | | |
| | Ground Level play components | | | | X | | | | |
| 240.2.1 | Are there ground level play components? (a component that is, both, entered and exited from ground level) | | | | | | | | |

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

Cite Element: **Playground** Yes No n/a Notes:

| | | | | | | | | | | | | | | | | | | | | | |
|--|--|-----------------------------------|--------------------------------------|-----------------------|---------------|---|-------------------------|---------|-----------|---------|-----------|-----------------------|---------------|---------------|---------------|----------------|--|---------------------------|--|--|--|
| 240.1.1 | Is one of each type of GLPC provided accessible and on the AR? | | | | | | | | X | | | | | | | | | | | | |
| 240.2.1 | Are GLPC's dispersed throughout the play area and integrated with other play components? | | | | | | | X | | | | | | | | | | | | | |
| 240.2.1 1008.4 1008.4.2 1008.4.5 | List all GROUND LEVEL PLAY COMPONENTS | 36" x 80" AR/surf. | 30 X 48 | 60" T.S | 11"-24" ent. | Supp-orts? n/a if entry is not required | R.R BP | S P I n | S L I D e | R O C K | S W I N G | C L I M B | M A I N P B P | I N T E R B P | O T H E R B P | C O M P. (+/-) | Notes: If surface is not compliant, answers assume surface correction | | | | |
| 1.play counter | | N | Y | Y | n/a | n/a | n/a | | | | | | | | X | | - | 54.5" OH (STP158, STP159) | | | |
| 2.motor cycle rocker | | Y | Y | Y | N | n/a | n/a | | | X | | | | | | | - | 27.5" (STP160) | | | |
| 3.dino rocker | | Y | Y | Y | Y | n/a | n/a | | | X | | | | | | | + | | | | |
| 4.truck rocker | | Y | Y | Y | N | n/a | n/a | | | X | | | | | | | - | 27" (STP161) | | | |
| 5.bucket 1 | | Y | Y | Y | N | Y | n/a | | | | X | | | | | | - | 37.5" (STP162) | | | |
| 6.bucket 2 | | Y | Y | Y | N | Y | n/a | | | | X | | | | | | - | 38.5" (STP163) | | | |
| 7.spinner | | Y | Y | Y | Y | n/a | n/a | X | | | | | | | | | + | | | | |
| 8.play table | | Y | Y | Y | Y | n/a | n/a | | | | | | | | X | | + | One side ext | | | |
| REACH RANGES for ground level: | | Ages 3 & 4: 20" to 36" | | | | | Ages 5 to 8: 18" to 40" | | | | | Ages 9 to 12: 16" 44" | | | | | | | | | |
| For usability of a talk tube or periscope from the ground reduce max reach by 8" to 10" (smart practice) | | | | | | | | | | | | | | | | | | | | | |
| Incentive Scoping GPC/EPC: | | | | | | | | | | | | | | | | | | | | | |
| If there is not a ramp to accessible EPC, OR if there is a ramp but it connects to less than 50% of EPC, AND if the ramp connects less than three types of EPC, <i>then apply the table below to determine the amount of accessible GPC needed</i> | | | | | | | | | | | | | | | | | | | | | |
| 240.2.1.2 | # EPC provided | Min # required to be on AR | Min # of types required on AR | Comply | Notes: | | | | | | | | | | | | | | | | |
| | 2 to 4 | 1 | 1 | | | | | | | | | | | | | | | | | | |
| | 5 to 7 | 2 | 2 | | | | | | | | | | | | | | | | | | |
| | 8 to 10 | 3 | 3 | | | | | | | | | | | | | | | | | | |
| | 11 to 13 | 4 | 3 | | | | | | | | | | | | | | | | | | |
| | 14 to 16 | 5 | 3 | Yes, with corrections | | | | | | | | | | | | | | | | | |
| | 17 to 19 | 6 | 3 | | | | | | | | | | | | | | | | | | |
| | 20 to 22 | 7 | 4 | | | | | | | | | | | | | | | | | | |

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

Cite Element: **Playground** Yes No n/a Notes:

| | | | | | |
|---------------|---|--|--|---|--|
| 206.2.2 | Sand Boxes: | | | X | |
| | Is there an AR connecting/adjacent to the border of sandbox? | | | | |
| | Is there a transfer system provided? OR Is there a raised sand table with knee clearance; OR is there an accessible sand play component along the AR? | | | X | |
| 1008.4.3 | Play Tables: | | | X | |
| | Is the play table 31" high max? | | | | |
| 1008.4.3 | Is there knee clearance 24" high and 17" deep X 30" wide? | | | X | |
| 1008.4.3 | Exception: Play tables for children 5 years and younger do not require knee clearance when there is CFS for a parallel approach is provided | | | X | |
| OTHER: | | | | | |

Rev. 02/11/2014