

CITE	ELEMENT: SWIMMING POOLS	YES	NO	n/a	NOTES
206.4.1	Are the entrances to all public areas accessible? (ie: concessions, first aid, guard stations)	X			
403.5.1	Is a 36" wide accessible route maintained on the pool deck surface?	X			
307.4	Is there at least 80" vertical head space along the deck AR?	X			
304.3.1 304.3.2	Are there sections of the route that are 60" wide and allowing for turning or T shaped?	X			
307.2	Is the pool deck area free of protruding objects? (nothing greater than 4" between 27-80" aff) (handrails can protrude 4.5")	X			
302.3/303.2	Is the AR clear of gaps and changes in level? (ie: expansion joints filled?)	X			
403.3	Is the slope of the deck surface along the AR no greater than 5% running or 2% cross and surface firm and stable? (can be up to 5% cross for drainage)	X			
305.3	Is there clear floor space around fixtures and operable parts? (30" by 48")			X	
308	Is at least one of each type of operable parts within reach range?			X	
702.1	If alarms are present; are audible/visual alarms in each public use area and common restrooms?			X	
904.4.1	Is there a 36" wide section of the service counter that is at 36" aff for a parallel approach, or 30" wide by 36" aff for forward approach?			X	
	Means of Entry:				
242.2	Are there at least 2 accessible means of entry for pools having greater than 300 linear feet of wall? Exc. Only one means of entry is required for wave pools, lazy rivers, sand bottom pools, and other water amusements			X	
242.2	Is there at least one accessible means of entry for pools with less than 300 linear feet of wall?	X			
242.2	If two means of entry are provided, are they different, and in differing locations? (best practice)			X	
1009.2	Pool Lifts:				

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

CITE	ELEMENT: SWIMMING POOLS	YES	NO	n/a	NOTES
1009.2.1	Is lift in a location where the water level does not exceed 48"?	X			
1009.2.7	Can lift be operated independently?	X			
1009.2.2	In the raised position, is the centerline of the seat located (over the deck) 16" min from pool edge?			x	Not installed
1009.2.3	Is there 36" of clear deck space parallel to the seat?	X			
1009.2.3	Starting from a point 12" behind the seat, does the space extend 48" forward?				
11B-1009.2.4	Does the seat height allow a stop at 16" min to 19" max aff and have a ridged back extending 12" high and have a restraint system?	X			
1009.2.5 1009.2.6	Is the seat min 16" wide and is there a footrest that moves with the seat?	X			
11B-1009.2.6	Does the seat have two armrests provided, and is the armrest opposite the water removable/ fold away?	X			
1009.2.8	Is lift designed so that it will submerge to a water depth of 18" min?	X			
1009.2.9	Does it have a weight capacity of 300 lbs. and have the capability of sustaining a static load of at least 1.5 times the rated load?	X			
1009.3	Sloped Entries:				
1009.3.2	At sloped entries, do they extend to a depth of 24" min and 30" max below the water level with at least one landing at the bottom of the sloped entry?			X	
1009.3.3	Are there two continuous handrails 34" to 38" aff, with top extension and correct grip surface and dimension (for wading pools, see below)			X	
1009.3.3	Are there handrails on each side with a clear width of 33" min to 38" max? Clear width does not apply to wave actions, leisure rivers, sand bottom pools and pools limited to user access in one area.			X	

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

CITE	ELEMENT: SWIMMING POOLS	YES	NO	n/a	NOTES
405.2	Is the running slope of the sloped entry no greater than 1:12 or 8.33%?			X	
405.3	Is the cross slope of the sloped entry no greater than 1:48 or 2%?			X	
smart practice	If there is a sloped entry, does the facility provide an aquatic W/C?			X	
1009.4	Transfer walls:			X	
1009.4.2	Is the height of the transfer wall 16" min to 19" max from the deck?			X	
1009.4.3	Is the depth of the wall 12" min to 16" max?			X	
1009.4.3	Is the length of the transfer wall 60" min and centered on clear deck space?			X	
1009.4.5	Is there at least one grab bar provided?			X	
1009.4.5	Is there a 1.5" space between grab bar and wall?			X	
1009.4.5	Is the gripping surface of the grab bar 4" min to 6" max above the wall?			X	
1009.4.5	Where one grab bar is provided is there a clearance of 24" min on both sides of the grab bar?			X	
1009.4.5	Where two grab bars are provided is the clearance between them 24" min?			X	
1009.4.5	Are the grab bars mounted perpendicular to the wall and do they extend the full depth of the transfer wall?			X	
1009.4.1	Is there clear deck space of 60" X 60" with a slope no greater than 1:48 at the base of the transfer wall?			X	
1009.4.4	Do the surfaces of the transfer walls have rounded edges?			X	
1009.5	Transfer Systems:				

CITE	ELEMENT: SWIMMING POOLS	YES	NO	n/a	NOTES
1009.5.1	Is a transfer platform provided at the head of the transfer system that is 19" min deep and 24" min wide?			X	
1009.5.2	Is there a transfer space at the base of the transfer platform 60"X60" mi. with a slope no greater than 1:48?			X	
1009.5.2	Is the side of the transfer platform unobstructed?			X	
1009.4.2	Is the height of the transfer platform 16" min to 19" max?			X	
1009.5.4/ 1009.5.6	Are the riser heights of the transfer steps no greater than 8" with a clear tread depth of 14" min and 17" max and width of 24"?			X	
1009.5.4	Is the last tread submerged 18" below water level?			X	
1009.5.7	Is at least one grab bar provided for the transfer steps?			X	
1009.5.7	Is the top of the rail 4" min to 6" max aff?			X	
1009.6	Pool Stairs:			X	
1009.6.1	Where there are pool stairs, do they comply with 504 (tread depth, nosings, etc.)? Exception: risers are not required to be 4" min to 7" max provided they are of a uniform height	X			9"-10"
1009.6.2	Is the width between the handrails 20" min to 24" max? (handrail ext. are not required.)		X		29" (STP146 , STP147)
	Specialties:				
242.3	Where wading pools are present, is there a sloped, no step entry extending to the deepest end of the pool? (handrails are not required)			X	
242.4	Where spas are present, is there at least one means of accessible entry via pool lift, transfer wall or a transfer system? (pool lifts in spas do not require footrests)			X	

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

CITE	ELEMENT: SWIMMING POOLS	YES	NO	n/a	NOTES
206.2.2	Where there are duplicate areas available to the public (sundecks) is at least one accessible?		X		No access to upper deck area (STP143)
602	Where drinking fountains are present, are they compliant? (see IAR for complete reference)			X	
	Permanent signs: complete signage checklist			X	
Other:	Includes shower area (STP145), handle at 48" (STP144)				

Rev. 07/31/13