Building/Year built: Siltanen Park
Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
Job#: R15025

Cite Element: Park Site Yes No n/a Notes:

Element: (ball field, etc)	**How many of each element at this site?**	**Is it designed for wheelchair use? (i.e.: surface, reach range, etc, see notes)**	**AR to element?**	**Does the AR extend to play surface/both sides of sport court?**	**Does the AR extend to player seating?**	**Does the AR extend to spectator seating?**	**Designated entry 32" for doorway/gate, 36" for entry w/o door with maneuvering clearance?**	**total accessible/ total (ex - 0/5)**	**Notes:** *RR: Forward unobstructed* - 15" to 48" (max 20" over object) *forward high obstructed* - max 44" for max reach over of 25" over 34" aff counter *Side unobstructed* - 15" to 48" (max 10" over object) *side high obstructed* - 46" for max of 24" over object (Safe harbor - existing RR - 9" to 54")
1.Garbage	10	Yes	Yes	n/a	n/a	n/a	n/a	10/10	
2. ball fields 1, 2	2	No	No	No	No	No	n/a	0/2	(STP92, STP93); stairs to bleachers (STP140)
3. drinking fountain	2	Yes	Yes	n/a	n/a	n/a	n/a	1/2	Accessible shares CFS with bench (STP112); single bowl (STP131)
4.adult softball and girls softball	2	No	No	No	n/a	No	n/a	0/2	dirt path to girls' bleachers (STP125, STP126)
5.horse shoes	2	No	No	No	n/a	n/a	n/a	0/2	Dirt (STP132)
6.majors field	1	No	No	No	No	No	Yes	0/1	Steps to dugouts (STP97, STP98), gravel to bleachers (STP94, STP95), steep route to field from both sides (STP28); Gap at gate to field (STP96); steps and dirt path to press box (STP102, STP103) ** considering putting lights, would trigger access req.
7.athetic field	1	No	No	No	n/a	n/a	n/	0/1	(STP122, STP123, STP124)

	Benches:				How many: 4

Property of Recreation Accessibility Consultants, LLC.

Building/Year built: Siltanen Park
Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
Job#: R15025

Cite	Element: Park Site	Yes	No	n/a	Notes:
					How many accessible: 1
1011.2.1	Is there clear floor space adjacent to the bench for wheelchair position?	X			(STP112) accessible shares CFS with drinking fountain
Smart practice	Is the seat height 17" to 19" above the ground?	X			
Smart practice	Is there a back support that extends the full length of the bench seat?	X			
Smart practice	Is there an armrest on at least one side?		X		
F245	Are at least 20% of benches accessible?	X			
	Picnic Tables:				How many: 0 How many accessible:

Rev: 04/9/2014

Property of Recreation Accessibility Consultants, LLC.