

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

CITE ELEMENT: SHELTERS/PICNIC AREAS

	Questions	Shelter: BBQ area	Picnic Area: Across from play area	Shelter/Picnic Area:
	If the route includes a ramp, refer to means of access checklist	n/a	n/a	
F245	If benches exist along the accessible route, are at least 20% or no less than 2 accessible? (best practice)	n/a	n/a	
F245	Are 20% of picnic tables accessible? (best practice)	0/5	1/9, but not on AR (STP109)	
401-403	Is there accessible entry into covered area or an AR to the picnic area?	No: steep slopes	No: grass	
302.3	Are all gaps <.5"?	Yes	n/a	
303.2	Are all changes in level <.25"?	Yes	n/a	
304.3.1, 304.3.2	Is there turning space of a circular 60" diameter min or a t-shaped turning space within a 60" square min with arms and base 36" wide min?	Yes	n/a	
206.2.2	Is there an AR to all shelter/picnic amenities?	No: 32" (STP117 , STP118) for 33"(STP115) deep to interior of grill area	No: 2 grills (STP107)	
	Are shelter/picnic amenities of an accessible design? (drinking fountain, hi-lo, grill in reach range, outlets in reach range, etc.)	No: drinking fountain not hi-lo (STP104); garbage cans (6) all ok	No	
308	Are operable parts of unique features w/in reach range?	No: counter: 38.5" high (STP114) Sink: no knee clearance	n/a	
307.2	Are all protrusions into the general circulation path <4"?	No: counter 8.5" (STP113)	n/a	
307.4	Is there 80" min overhead clearance?	Yes	n/a	
	Portable Toilets:	n/a	n/a	