

MULTIPLE DOORS CHECKLIST

Cite:	Question:	Door: E Door #: Pump room	Door: E Door #: Guard room		Door: E Door #: Maintenance		Door: E Door #: Shelter storage	Door: I Door #: Second storage	Door: I Door #: Closet in storage	Door: E Door #: Snack shop entry
	<b>If a double door, measure only the active leaf</b>									
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: storage ( <a href="#">STP166</a> )	No: desk on pull ( <a href="#">STP168</a> ); storage back on pull ( <a href="#">STP188</a> )		Yes		Yes	No: shelf and storage ( <a href="#">STP174</a> , <a href="#">STP194</a> )	No: wall on pull ( <a href="#">STP177</a> )	Yes
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	Yes		No: 3.9% slope ( <a href="#">STP171</a> , <a href="#">STP172</a> )		Yes	Yes	Yes	No: 4.1% ( <a href="#">STP178</a> , <a href="#">STP179</a> )
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes		Yes		Yes	Yes	Yes	Yes
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	No: 29.5" ( <a href="#">STP167</a> )	No: 29" ( <a href="#">STP169</a> )		Yes		Yes	Yes	Yes	Yes
404.2.3	If door is 24" D, is it 36" W	n/a	n/a		n/a		n/a	n/a	n/a	n/a
303.2	Change in level < 1/4"	No: 4.25" ( <a href="#">STP165</a> )	No: 3.5" ( <a href="#">STP170</a> )		No: 8.25" ( <a href="#">STP173</a> )		No: 1.5" ( <a href="#">STP175</a> )	Yes	n/a	Yes
404.2.5	Thresholds < 1/2 "	No: lipped	No: lipped		n/a		n/a	n/a	n/a	n/a
404.2.5	If existing threshold is 3/4" is it beveled at 1:2? (exception)	n/a	n/a		n/a		n/a	n/a	n/a	n/a
302.2	If carpeted is pile < 1/2"	n/a	n/a		n/a		n/a	Yes	n/a	n/a
302.3	If openings in floor, <1/2" and perpendicular	n/a	n/a		n/a		n/a	n/a	n/a	Yes
309.4; 404.2.7	Door hardware compliant?	No: knob	No: knob		No: knob		Yes	No: knob ( <a href="#">STP176</a> )	No: knob	No: knob

Smart practice	Hazardous areas knurled handle	n/a	n/a		n/a		n/a	n/a	n/a	n/a
11B-404.2.7	Hardware height (34"-44")	Yes	Yes		Yes		Yes	Yes	Yes	Yes
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a		n/a		n/a	n/a	n/a	n/a
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a		n/a		n/a	n/a	n/a	n/a
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a		n/a		n/a	n/a	n/a	n/a
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a		n/a		n/a	n/a	n/a	n/a
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	n/a		n/a		n/a	n/a	n/a	n/a
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes		Yes		Yes	Yes	Yes	Yes
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above 66")	n/a	n/a		n/a		n/a	n/a	n/a	n/a
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a		n/a		n/a	n/a	n/a	n/a
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a		n/a		n/a	n/a	n/a	n/a

404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a		n/a		n/a	n/a	n/a	n/a
Other:										

Rev. 04/21/14

Cite:	Question:	Door: I Door #: Concession heater and furnace	Door: E Door #: Preschool	Door: I Door #: Parent ed room	Door: E Door #: Stairway		Door: E Door #: Women's RR	Door: E Door #: Men's RR		
<b>If a double door, measure only the active leaf</b>										
404.2.4 404.2.4.1 404.2.4.2	Maneuvering clr. around doors/entries	No: storage ( <a href="#">STP197</a> , <a href="#">STP198</a> )	Yes	No: desk on pull ( <a href="#">STP200</a> )	No: storage and cabinet, chairs on push ( <a href="#">STP182</a> )		No: wall on push	Yes		
404.2.4.4	Do floor surfaces in MC comply with 302 (slope, CIL, gaps)?	Yes	No: 11.5% ( <a href="#">STP55</a> , <a href="#">STP180</a> )	Yes	Yes		Yes	Yes		
307.4	80" Head Clearance (excl. closer; min 78")	Yes	Yes	Yes	Yes		Yes	Yes		
404.2.3	Door width 32"; with no projections > 4" between 34" and 80"?	Yes	Yes	Yes	Yes		Yes	Yes		
404.2.3	If door is 24" D, is it 36" W	n/a	n/a	n/a	n/a		n/a	n/a		
303.2	Change in level < 1/4"	n/a	Yes	n/a	Yes		No: 1" ( <a href="#">STP183</a> )	No: 1"		
404.2.5	Thresholds < 1/2 "	n/a	Yes	n/a	Yes		n/a	n/a		
404.2.5	If existing threshold is 3/4" is it beveled at 1:2?	n/a	n/a	n/a	n/a		n/a	n/a		

	(exception)									
302.2	If carpeted is pile < ½"	n/a	n/a	n/a	n/a		n/a	n/a		
302.3	If openings in floor, ≤1/2" and perpendicular	n/a	n/a	n/a	n/a		n/a	n/a		
309.4; 404.2.7	Door hardware compliant?	Yes	Yes	Yes	Yes		No: knob	No: knob		
Smart practice	Hazardous areas knurled handle	n/a	n/a	n/a	n/a		n/a	n/a		
11B-404.2.7	Hardware height (34"-44")	Yes	Yes	Yes	Yes		Yes	Yes		
404.3.5	Is the CFS at the power door controls located outside of any door swing?	n/a	n/a	n/a	n/a		n/a	n/a		
11B-404.3.5	Do power doors have two push plates, one at 7"-8" aff and the other 30"-44" aff?	n/a	n/a	n/a	n/a		n/a	n/a		
404.2.9	Pull Force; int. hinged doors; sliding or folding doors (5 lbf)	n/a	n/a	n/a	n/a		n/a	n/a		
11B-404.2.9	Exterior doors pull force (5 lbf) or 8.5 lbf if power doors exist	n/a	n/a	n/a	n/a		No: 10#	No: 11#		
404.2.8	Door closers: 3 sec. from 70 to 3"	n/a	n/a	n/a	n/a		Yes	No		
404.2.10	Is the surface of the door from floor to 10" aff on the push side smooth or have a kick plate? (horizontal gap 1/16" max)	Yes	Yes	Yes	Yes		Yes	Yes		
404.2.11	Do doors w/side lights for view have at least one panel max 43" aff? (exc. if bottom above	n/a	n/a	n/a	n/a		n/a	n/a		

Building/Year built: Siltanen Park  
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito  
 Job#: R15025

	66")									
404.2.8.2	For spring hinges – closer 1.5 sec. from 70 to close	n/a	n/a	n/a	n/a		n/a	n/a		
404.2.6	Series of doors clearance (48" clear width, doors open)	n/a	n/a	n/a	n/a		n/a	n/a		
404.2.7	Sliding doors hardware usable without tight pinch or grasp and on both sides?	n/a	n/a	n/a	n/a		n/a	n/a		
Other:										