

Cite	Element: Concessions	Yes	No	n/a	Notes:
206.2.5	Is there an accessible route to all dining areas indoors and out?			X	
226	Are at least 5% of the seating/standing areas accessible?			X	
305.3/306.3 306.2	Is there clear floor space positioned for a forward approach to the dining tables with knee and toe clearances?			X	
904.5.2	Are tray slides between 28" and 34"?			X	
904.4	Is there a 36" wide, 34" high service counter area?		X		49.5" (STP134)
305 904.4.1	Is there clear floor space for a parallel approach to the counter?	X			
904.4.2	If the 36" high portion is only 30" long, is there clear floor space for a forward approach with toe and knee clearances?			X	
902.4	Children's facilities: Are table tops 26-30" aff with clear floor space positioned for a forward approach with knee clearance of 24" min aff?			X	
Smart practice	Are the menu characters of contrasting color, of the correct size and have pictures?		X		Letters only (STP135)
804.6.5.3	Do the ovens have controls on the front panel?		X		Back (STP137)
804.2.1	<i>Concessions w/ovens:</i> In a pass through kitchen is there 40" min clearance between the furthest projecting face of all apposing base cabinets, counter tops, appliances or walls, excluding hardware?		X		57" (STP138 , STP139)
804.2.2	<i>In a U-shaped kitchen, is there a 60" min Clearance?</i>				
305	Is there CFS to allow for a forward or parallel approach to counters?	X			
804.5/811	Is at least 50% of cabinet shelf storage space within reach range? (15-48")	X			
212.3	Sinks: Are at least 5% but no less than one of each type of sink in each accessible room or space accessible?		X		
606.3	Is the sink installed with the front of the higher of the rim or counter surface 34" max aff?		X		35.75" (STP142)
309	Does the sink have push/lever hardware?	X			
606.5	Is there insulation on all exposed pipes?			X	
305	Is there clear floor space around all sinks, works surfaces, operable parts and appliances?		X		Counter back at sink (STP141)
606.2	Is there knee clearance 30"W, 27" H and 8"D provided at all sinks? Parallel approach ok if no oven provided.		X		Cabinet (STP141)

Building/Year built: Siltanen Park
 Date: 11/12/15

Team: Shelley Zuniga, Dana Esposito
 Job#: R15025

Cite	Element: Concessions	Yes	No	n/a	Notes:
804.6.6	In refrigerator/freezers is at least 50% of the freezer space 54" max aff?	X			
403.5.1	Room/Space: Is there a 36" wide access aisle to move freely about all aspects of the concession spaces?	X			
307.4	Is there at least 80" vertical head space along the access aisle?		X		Menu at 74" (STP133 , STP135)
403.5.3	Are there sections of the route that are 60" wide to allow for turning?	X			
307.2	Is the room free of protruding objects? (<4", bet. 27-80" aff)	X			
302.1	Are the floor surfaces firm, stable and slip resistant?	X			
303.4	Where there are changes in level greater than ½" is there a ramp provided that has a slope no greater than 1:12?	X			
804.6.1	Is there clear floor space around fixtures, operable parts, and appliances?	X			
804.6.3	(C.F.S at dishwasher may be adjacent to the dishwasher door; however the door can not obstruct the clear floor space, clear floor space at work surfaces and appliances can be shared)				
308	Is there at least one of each type of operable part within reach range?	X			
702	If an alarm exists and concession is operated by volunteers; is it a visual/audible alarm?			X	
207.1	Does the concession have an accessible means of egress?	X			
	Is the concession operated by paid employees, or by volunteers?	Volunteers			

Rev. 07/31/13