

Building/Year built: Skypark/Rec Center  
 Date: 11/10/2015

Team: Dana Esposito and Shelley Zuniga  
 Job#: R15025

Cite Element: Park Site Yes No n/a Notes:

Element: (ball field, etc)	How many of each element at this site?	Is it designed for wheelchair use? (i.e.: surface, reach range, etc, see notes)	AR to element?	Does the AR extend to play surface/both sides of sport court?	Does the AR extend to player seating?	Does the AR extend to spectator seating?	Designated entry 32" for doorway/gate, 36" for entry w/o door with maneuvering clearance?	total accessible/ total (ex - 0/5)	Notes: RR: Forward unobstructed - 15" to 48" (max 20" over object) forward high obstructed - max 44" for max reach over of 25" over 34" aff counter Side unobstructed - 15" to 48" (max 10" over object) side high obstructed - 46" for max of 24" over object (Safe harbor - existing RR - 9" to 54")
1. Drinking fountain	5	No	Yes	n/a	n/a	n/a	n/a	1/5	Not hi-lo, button not working 38.5" spout ( <a href="#">SP69</a> , <a href="#">SP71</a> ); by RR, lo bowl only ( <a href="#">SP85</a> ); off AR ( <a href="#">SP90</a> , <a href="#">SP84</a> )
2. skate park	1	Yes	Yes	Yes	No	Yes	Yes	1/1	Spectator seating ( <a href="#">SP70</a> ); ( <a href="#">SP74</a> , <a href="#">SP75</a> )
3. garbage cans	16	Yes	Yes	n/a	n/a	n/a	n/a	11/16	( <a href="#">SP82</a> )
4. soccer	4	No	Yes	No	n/a	n/a	n/a	0/6	( <a href="#">SP80</a> , <a href="#">SP81</a> )
5. tennis	4	Yes	Yes	No	Yes	Yes	Yes	4/4	( <a href="#">SP94</a> , <a href="#">SP95</a> )
6. bocce	2	Yes	Yes	Yes	Yes	No	Yes	2/2	2 of 4 tables at bocce are accessible ( <a href="#">SP89</a> )
7. grill station	1	No	Yes	n/a	n/a	n/a	n/a	0/1	Grill surfaces high at 36" ( <a href="#">SP232</a> ), counter at 41" ( <a href="#">SP231</a> ); hand crank at 25" across ( <a href="#">SP235</a> , <a href="#">SP236</a> )
8. basketball	2, ½ ct	Yes	Yes	Yes	Yes	n/a	n/a	2/2	
9. portable toilet	1	No	Yes	n/a	n/a	n/a	n/a	0/1	
10. bike racks	2	n/a	No	n/a	n/a	n/a	n/a	0/2	( <a href="#">SP92</a> )

<b>Benches:</b>					How many: 13
-----------------	--	--	--	--	--------------

Building/Year built: Skypark/Rec Center  
 Date: 11/10/2015  
 Cite Element: Park Site

Team: Dana Esposito and Shelley Zuniga  
 Job#: R15025

Yes No n/a Notes:

					How many accessible: 3
1011.2.1	Is there clear floor space adjacent to the bench for wheelchair position?	X			( <a href="#">SP72</a> )
Smart practice	Is the seat height 17" to 19" above the ground?	X			1 at 14" ( <a href="#">SP76</a> , <a href="#">SP77</a> )
Smart practice	Is there a back support that extends the full length of the bench seat?	X			
Smart practice	Is there an armrest on at least one side?	X			
F245	Are at least 20% of benches accessible?	x			
	<b>Picnic Tables:</b>				How many: 5 How many accessible: 1
F245	Do picnic tables comply with 1011?	X			
1011.4	Does each accessible picnic table provide at least one wheelchair space with knee space 27" high, 30" wide and 9" deep?	X			
1011.4	Does the wheelchair space have toe clearance 9" high minimum and that extends 17" min and 25" max deep?	X			
1011.2.1	Is there 36" minimum clear space provided around the usable portion of table? (measured from the back edge of the seat)		X		In grass
1011.2.2 1011.3.3	Is the surface of the clear space firm and stable with max slope 2.08% in all directions?		X		

Rev: 04/9/2014