

CITE                    **ELEMENT: SHELTERS/PICNIC AREAS**

	Questions	Shelter/Picnic Area: Round shelter near building	Picnic Area: tables with grill	Shelter/Picnic Area: Round shelter near play area
	If the route includes a ramp, refer to means of access checklist	n/a	n/a	n/a
F245	If benches exist along the accessible route, are at least 20% or no less than 2 accessible? (best practice)	n/a	n/a	n/a
F245	Are 20% of picnic tables accessible? (best practice)	0/8 ( <a href="#">SP229</a> )	No 0/3	No: 0/7 ( <a href="#">SP239</a> )
401-403	Is there accessible entry into covered area or an AR to the picnic area?	Yes	No – in grass ( <a href="#">SP237</a> )	Yes
302.3	Are all gaps <.5”?	Yes	n/a	Yes
303.2	Are all changes in level <.25”?	Yes	n/a	Yes
304.3.1, 304.3.2	Is there turning space of a circular 60" diameter min or a t-shaped turning space within a 60" square min with arms and base 36" wide min?	Yes	No	No: table placement ( <a href="#">SP238</a> )
206.2.2	Is there an AR to all shelter/picnic amenities?	Yes	No – grills	Yes
	Are shelter/picnic amenities of an accessible design? (drinking fountain, hi-lo, grill in reach range, outlets in reach range, etc.)	n/a	No	Yes
308	Are operable parts of unique features w/in reach range?	n/a	n/a	n/a
307.2	Are all protrusions into the general circulation path <4”?	n/a	n/a	n/a
307.4	Is there 80” min overhead clearance?	Yes	Yes	Yes
	<b>Portable Toilets:</b> If a portable toilet is provided, refer to single user checklist	n/a	n/a	n/a

Rev. 07/31/13

CITE                    **ELEMENT: SHELTERS/PICNIC AREAS**

	Questions	Shelter/Picnic Area: Chess shelter
	If the route includes a ramp, refer to means of access checklist	n/a
F245	If benches exist along the accessible route, are at least 20% or no less than 2 accessible? (best practice)	n/a
F245	Are 20% of picnic tables accessible? (best practice)	No: 0/3 due to center post 12" knee depth ( <a href="#">SP241</a> , <a href="#">SP243</a> )
401-403	Is there accessible entry into covered area or an AR to the picnic area?	Yes
302.3	Are all gaps <.5"?	No: large gaps at utility drain ( <a href="#">SP240</a> )
303.2	Are all changes in level <.25"?	Yes
304.3.1, 304.3.2	Is there turning space of a circular 60" diameter min or a t-shaped turning space within a 60" square min with arms and base 36" wide min?	Yes
206.2.2	Is there an AR to all shelter/picnic amenities?	Yes
	Are shelter/picnic amenities of an accessible design? (drinking fountain, hi-lo, grill in reach range, outlets in reach range, etc.)	Yes
308	Are operable parts of unique features w/in reach range?	n/a
307.2	Are all protrusions into the general circulation path <4"?	n/a
307.4	Is there 80" min overhead clearance?	Yes
	<b>Portable Toilets:</b> If a portable toilet is provided, refer to single user checklist	n/a