

| | Rooms/Spaces: E = denotes employee space P=public | fl#: P file storage | fl#: E reception | fl#: P break room | fl#: P break storage | fl#: E division manage r office | Notes: E = employee; P = public |
|--------------------|---|---------------------------|---------------------|-------------------------|----------------------------|--|---|
| 403.5.1 | Is there a 36" wide access aisle to move freely about the room and to all aspects of the room/space? (can reduce to 32" for a max of 24" if there is CFS on either side) | No | Yes | Yes | Yes | Yes | File: 33.5" x 42" (SP190 , SP191) |
| 307.4 | Is there at least 80" vertical head space along the accessible route? | Yes | Yes | Yes | Yes | Yes | |
| 304.3.1 304.3.2 | Are there sections of the route that are 60" wide and allowing for turning or T shaped? (60" square w/36" arms) | No | Yes | No | Yes | Yes | |
| 307.2 | Is the room free of protruding objects? (nothing greater than 4" between 27"-80" aff) (handrails can protrude 4.5") | Yes | Yes | Yes | No | Yes | Break storage: hose and water heater (SP204 , SP205) |
| 302.1 | Are the floor surfaces of the room/space firm, stable and slip resistant? | Yes | Yes | Yes | Yes | Yes | |
| 302.2 | If carpeted, are edges securely fastened, and pile < .5" | n/a | Yes | n/a | n/a | Yes | |
| 303.2 303.3 | Are CIL .25" max? If CIL is between .25" and .5" is beveled w/max slope 1:2? | n/a | n/a | n/a | n/a | n/a | |
| 303.4 | Where there are changes in level greater than .5" is there a ramp provided that has a slope no greater that 1:12? | n/a | n/a | n/a | n/a | n/a | |
| 302.3 | Are any gaps in the floor .5" or less? (.5" elongated gaps must be perpendicular to path of travel) | n/a | n/a | n/a | n/a | n/a | |
| 403.3 | Is the slope of the floor surface no greater than 5% running or 2.08% cross and surface firm, stable and slip resistant? | n/a | n/a | n/a | Yes | Yes | |
| 305.3 | Is there clear floor space around fixtures and operable parts? (30" by 48") | n/a | Yes | Yes | No | No | Break storage: storage (SP206) Division: bookshelf chairs in way (SP209) |
| 308 | Is at least one of each type of operable parts within reach range? (ie: windows) <i>Forward unobstructed</i> - 15" to 48" (max 20" over object); <i>forward high obstructed</i> - max 44" for max reach over of 25" <i>Side unobstructed</i> - 15" to 48" (max 10" over object); <i>side high obstructed</i> - 46" for max of 24" over object; EXC - 36" to top of washer/dryers; 54" to fuel dispensers | n/a | Yes | No | Yes | Yes | Break: paper towels 54" over sink (SP198 , SP199); microwave at 65" (SP200 , SP201) |

CITE ELEMENT: ROOMS/SPACES

Yes/No/n/a

| | | | | | | | |
|--------------------|--|-------------------|----------------------|---------------|-----------------|---------------------------|--|
| | (Safe harbor - existing RR - 9" to 54") | | | | | | |
| 309.4 | Are operable parts usable w/out a tight pinch or grasp? (ie: windows, switches) | n/a | Yes | Yes | Yes | Yes | |
| 702.1 | If an alarm exists in public room is it a visual/audible alarm? (excluding closets) | n/a | n/a | No | n/a | n/a | Break: not in room |
| 701.1 | If an employee space, is the room within hearing distance of an audible alarm? (n/a for 1991) | n/a | Yes | n/a | n/a | Yes | |
| 226.1 | Is there a portion of any work surface that is 30" w and 34" high with knee and toe clearance? (public spaces only) | n/a | n/a | n/a | n/a | n/a | |
| 606.3 | If there is a sink, is it of compliant height of 34" w/CFS? (does not apply to mop basins, utility sinks, or bar sinks) | n/a | n/a | n/a | n/a | n/a | Break: sink at 37" (SP202 , SP203) |
| OTHER: | | | | | | | |
| | Rooms/Spaces: E = denotes employee space P=public | fl#: E school-age | fl#: E closet in all | fl#: E sports | fl#: P rec room | fl#: E right storage shed | Notes: E = employee; P = public |
| 403.5.1 | Is there a 36" wide access aisle to move freely about the room and to all aspects of the room/space? (can reduce to 32" for a max of 24" if there is CFS on either side) | No | No | No | Yes | No | School: storage and table (SP211 , SP212) Closet: no entry (SP214) sports: reduces to 22" and storage (SP217 , SP218) right shed: storage |
| 307.4 | Is there at least 80" vertical head space along the accessible route? | Yes | | Yes | Yes | Yes | |
| 304.3.1 304.3.2 | Are there sections of the route that are 60" wide and allowing for turning or T shaped? (60" square w/36" arms) | Yes | | No | Yes | No | Sports: storage |
| 307.2 | Is the room free of protruding objects? (nothing greater than 4" between 27"-80" aff) (handrails can protrude 4.5") | Yes | | Yes | Yes | Yes | |
| 302.1 | Are the floor surfaces of the room/space firm, stable and slip resistant? | Yes | | Yes | Yes | Yes | |
| 302.2 | If carpeted, are edges securely fastened, and pile < .5" | Yes | | Yes | n/a | n/a | |

CITE

ELEMENT: ROOMS/SPACES

Yes/No/n/a

| | | | | | | | |
|--------|---|-----|--|-----|-----|-----|---|
| 303.2 | Are CIL .25" max? If CIL is between .25" and .5" is beveled w/max slope 1:2? | n/a | | n/a | n/a | n/a | |
| 303.3 | | | | | | | |
| 303.4 | Where there are changes in level greater than .5" is there a ramp provided that has a slope no greater than 1:12? | n/a | | n/a | n/a | n/a | |
| 302.3 | Are any gaps in the floor .5" or less? (.5" elongated gaps must be perpendicular to path of travel) | n/a | | n/a | n/a | n/a | |
| 403.3 | Is the slope of the floor surface no greater than 5% running or 2.08% cross and surface firm, stable and slip resistant? | Yes | | Yes | Yes | n/a | |
| 305.3 | Is there clear floor space around fixtures and operable parts? (30" by 48") | No | | Yes | Yes | n/a | School: table at light and outlet (SP213) |
| 308 | Is at least one of each type of operable parts within reach range? (ie: windows) <i>Forward unobstructed</i> - 15" to 48" (max 20" over object); <i>forward high obstructed</i> - max 44" for max reach over of 25" <i>Side unobstructed</i> - 15" to 48" (max 10" over object); <i>side high obstructed</i> - 46" for max of 24" over object; EXC - 36" to top of washer/dryers; 54" to fuel dispensers (Safe harbor - existing RR - 9" to 54") | Yes | | Yes | Yes | n/a | |
| 309.4 | Are operable parts usable w/out a tight pinch or grasp? (ie: windows, switches) | Yes | | Yes | Yes | n/a | |
| 702.1 | If an alarm exists in public room is it a visual/audible alarm? (excluding closets) | n/a | | n/a | n/a | n/a | |
| 701.1 | If an employee space, is the room within hearing distance of an audible alarm? (n/a for 1991) | Yes | | Yes | n/a | n/a | |
| 226.1 | Is there a portion of any work surface that is 30" w and 34" high with knee and toe clearance? (public spaces only) | n/a | | n/a | No | n/a | Rec: 26.75" (SP219 , SP220) |
| 606.3 | If there is a sink, is it of compliant height of 34" w/CFS? (does not apply to mop basins, utility sinks, or bar sinks) | n/a | | n/a | n/a | n/a | |
| OTHER: | | | | | | | |

| | | | | | | |
|--|-----------------------------|---------------------------|----------|----------|----------|---------------------------------|
| Rooms/Spaces: E = denotes employee space P=public | fl#: E center storage | fl#: E left storage | fl#: P/E | fl#: P/E | fl#: P/E | Notes: E = employee; P = public |
|--|-----------------------------|---------------------------|----------|----------|----------|---------------------------------|

CITE

ELEMENT: ROOMS/SPACES

Yes/No/n/a

| | | shed | shed | | | | |
|--------------------|---|------|------|--|--|--|--|
| 403.5.1 | Is there a 36" wide access aisle to move freely about the room and to all aspects of the room/space? (can reduce to 32" for a max of 24" if there is CFS on either side) | No | Yes | | | | Center: storage (SP221) |
| 307.4 | Is there at least 80" vertical head space along the accessible route? | Yes | Yes | | | | |
| 304.3.1 304.3.2 | Are there sections of the route that are 60" wide and allowing for turning or T shaped? (60" square w/36" arms) | No | Yes | | | | Center: storage |
| 307.2 | Is the room free of protruding objects? (nothing greater than 4" between 27"-80" aff) (handrails can protrude 4.5") | Yes | No | | | | Left shed: shelves 13.5" (SP222 , SP223), microwave shelf (SP224) |
| 302.1 | Are the floor surfaces of the room/space firm, stable and slip resistant? | Yes | Yes | | | | |
| 302.2 | If carpeted, are edges securely fastened, and pile < .5" | n/a | n/a | | | | |
| 303.2 303.3 | Are CIL .25" max? If CIL is between .25" and .5" is beveled w/max slope 1:2? | n/a | n/a | | | | |
| 303.4 | Where there are changes in level greater than .5" is there a ramp provided that has a slope no greater than 1:12? | n/a | n/a | | | | |
| 302.3 | Are any gaps in the floor .5" or less? (.5" elongated gaps must be perpendicular to path of travel) | n/a | n/a | | | | |
| 403.3 | Is the slope of the floor surface no greater than 5% running or 2.08% cross and surface firm, stable and slip resistant? | n/a | n/a | | | | |
| 305.3 | Is there clear floor space around fixtures and operable parts? (30" by 48") | n/a | No | | | | Left shed: not at shelves (SP226) |
| 308 | Is at least one of each type of operable parts within reach range? (ie: windows) <i>Forward unobstructed</i> - 15" to 48" (max 20" over object); <i>forward high obstructed</i> - max 44" for max reach over of 25" <i>Side unobstructed</i> - 15" to 48" (max 10" over object); <i>side high obstructed</i> - 46" for max of 24" over object; EXC - 36" to top of washer/dryers; 54" to fuel dispensers (Safe harbor - existing RR - 9" to 54") | n/a | No | | | | Left shed: high tool hooks (SP227); high microwave (SP224); overhead storage (SP228) |
| 309.4 | Are operable parts usable w/out a tight pinch or grasp? (ie: windows, switches) | n/a | n/a | | | | |
| 702.1 | If an alarm exists in public room is it a visual/audible alarm? (excluding closets) | n/a | n/a | | | | |

Building/Year built: Skypark/Rec Center
 Date: 11/10/2015

Team: Dana Esposito and Shelley Zuniga
 Job#: R15025

CITE ELEMENT: ROOMS/SPACES

Yes/No/n/a

| | | | | | | | |
|--------|---|-----|-----|--|--|--|--|
| 701.1 | If an employee space, is the room within hearing distance of an audible alarm? (n/a for 1991) | n/a | n/a | | | | |
| 226.1 | Is there a portion of any work surface that is 30" w and 34" high with knee and toe clearance? (public spaces only) | n/a | n/a | | | | |
| 606.3 | If there is a sink, is it of compliant height of 34" w/CFS? (does not apply to mop basins, utility sinks, or bar sinks) | n/a | n/a | | | | |
| OTHER: | | | | | | | |

Rev. 04/21/14